

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
1		system data	bTriggerScada2PLC	Heart beat from BMS to the local PLC; auto returns to FALSE	W			bool	TRUE = on	32768	0	(0x03; 0x06)
2		system data	bResetErrors	reset all errors	W			bool	TRUE = reset	32768	1	(0x03; 0x06)
3		system data	bLight	switch on internal maintenance lighting	W			bool	TRUE = on	32768	2	(0x03; 0x06)
4		system data	bTestFireDampers	starts test of all fire dampers	W			bool	TRUE = start	32768	3	(0x03; 0x06)
5	D	system data	eSystemMode	AHU operation mode	W			uint	0 = off; 1 = manual mode; 2 = auto mode	32769		(0x03; 0x06)
6	S	system data	fTempOutdoor	send present value outdoor temperature to local PLC	W	°C	10	int		32770		(0x03; 0x06)
7	D	system data	nResetErrors	reset all errors, auto returns to 0	W			int	1 = reset	32771		(0x03; 0x06)
8		setpoints	bStandbySetpoint	force AHU to standby mode	W			bool	TRUE = standby	32791	0	(0x03; 0x06)
9	D	setpoints	fFanSUPSetpoint	setpoint of the supply air fan, unit depends on control strategy	W	Pa, m³/h, ppm		uint		32792		(0x03; 0x06)
10	D	setpoints	fFanETASetpoint	setpoint of the extract air fan, unit depends on control strategy	W	Pa, m³/h, ppm		uint		32793		(0x03; 0x06)
11	D	setpoints	fTempMinSetpoint	setpoint of the min. air temperature	W	°C	10	int		32794		(0x03; 0x06)
12	D	setpoints	fTempMaxSetpoint	setpoint of the max. air temperature	W	°C	10	int		32795		(0x03; 0x06)
13	S	setpoints	fHumMinSetpoint	setpoint of the min. air humidity	W	%	10	uint		32796		(0x03; 0x06)
14	S	setpoints	fHumMaxSetpoint	setpoint of the max. air humidity	W	%	10	uint		32797		(0x03; 0x06)
15		setpoints	rInputPowerDemandIC	power demand 0...100% of the integrated refrigerating (standalone only)	W	%		uint		32798		(0x03; 0x06)
16		setpoints	rInputPowerDemandRac	power demand 0...100% of the run around coil system (standalone only)	W	%		uint		32799		(0x03; 0x06)
17		setpoints	rSupplyAirFlowRac	supply air volume flow to the run around coil system (standalone only)	W	m³/h		uint		32800		(0x03; 0x06)
18	S	settings	fSetTempSUPMin	setpoint of the min. supply air temperature	W	°C	10	int		32808		(0x03; 0x06)
19	S	settings	fSetTempSUPMax	setpoint of the max. supply air temperature	W	°C	10	int		32809		(0x03; 0x06)
20	S	settings	fSetHumSUPMin	setpoint of the min. supply air humidity	W	%rH	10	int		32810		(0x03; 0x06)
21	S	settings	fSetHumSUPMax	setpoint of the max. supply air humidity	W	%rH	10	int		32811		(0x03; 0x06)
22		system data	bTriggerPLC2Scada	heart beat from local PLC to the BMS	R			bool	TRUE = on	32768	0	(0x04)
23		system data	bLight	internal mainenance lighting	R			bool	TRUE = on	32768	1	(0x04)
24		system data	bExternalLock	ext. lock of the AHU	R			bool	TRUE = ok	32768	2	(0x04)
25	S	system data	bVoltageError	voltage error	R			bool	TRUE = ok	32768	3	(0x04)
26	S	system data	bMainFuse	main fuse error	R			bool	TRUE = ok	32768	4	(0x04)
27	S	system data	bFireAlarm	error triggered fire alarm	R			bool	TRUE = ok	32768	5	(0x04)
28		system data	bModbuslineError	error modbus line	R			bool	TRUE = ok	32768	6	(0x04)
29	S	system data	bFrostProctection	error triggered frost protection	R			bool	TRUE = ok	32768	7	(0x04)
30	D	system data	eEventNotification	notification of alarm class	R			uint	0 = no alarm; 1 = warning (B-alarm); 2 = critical (A-alarm)	32769		(0x04)
31	S	system data	fTempOutdoor	present value outdoor air temperature	R	°C	0.1	int		32770		(0x04)
32		system data	bSmokeDetector1	triggered smoke detector 1	R			bool	TRUE = ok	32771	0	(0x04)
33		system data	bSmokeDetector2	triggered smoke detector 2	R			bool	TRUE = ok	32771	1	(0x04)
34		system data	bSmokeDetector3	triggered smoke detector 3	R			bool	TRUE = ok	32771	2	(0x04)
35		system data	bSmokeDetector4	triggered smoke detector 4	R			bool	TRUE = ok	32771	3	(0x04)
36		system data	bSmokeDetector5	triggered smoke detector 5	R			bool	TRUE = ok	32771	4	(0x04)
37		system data	bSmokeDetectorDirty1	smoke detector 1 is dirty	R			bool	TRUE = ok	32771	5	(0x04)
38		system data	bSmokeDetectorDirty2	smoke detector 2 is dirty	R			bool	TRUE = ok	32771	6	(0x04)
39		system data	bSmokeDetectorDirty3	smoke detector 3 is dirty	R			bool	TRUE = ok	32771	7	(0x04)
40		system data	bSmokeDetectorDirty4	smoke detector 4 is dirty	R			bool	TRUE = ok	32771	8	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
41		system data	bSmokeDetectorDirty5	smoke detector 5 is dirty	R			bool	TRUE = ok	32771	9	(0x04)
42		system data	extAlarm1	State of the ext. alarm number 1, polarity depends on configuration	R			bool		32783	0	(0x04)
43		system data	extAlarm2	State of the ext. alarm number 2, polarity depends on configuration	R			bool		32783	1	(0x04)
44		system data	extAlarm3	State of the ext. alarm number 3, polarity depends on configuration	R			bool		32783	2	(0x04)
45		system data	extAlarm4	State of the ext. alarm number 4, polarity depends on configuration	R			bool		32783	3	(0x04)
46		system data	extAlarm5	State of the ext. alarm number 5, polarity depends on configuration	R			bool		32783	4	(0x04)
47		system data	extAlarm6	State of the ext. alarm number 6, polarity depends on configuration	R			bool		32783	5	(0x04)
48		system data	extAlarm7	State of the ext. alarm number 7, polarity depends on configuration	R			bool		32783	6	(0x04)
49		system data	extAlarm8	State of the ext. alarm number 8, polarity depends on configuration	R			bool		32783	7	(0x04)
50		system data	extAlarm9	State of the ext. alarm number 9, polarity depends on configuration	R			bool		32783	8	(0x04)
51		system data	extAlarm10	State of the ext. alarm number 10, polarity depends on configuration	R			bool		32783	9	(0x04)
52		measurement data	fHumRoom1	present value room humidity 1	R	%rH	0.1	int		32785		(0x04)
53		measurement data	fHumRoom2	present value room humidity 2	R	%rH	0.1	int		32786		(0x04)
54		measurement data	fHumRoom3	present value room humidity 3	R	%rH	0.1	int		32787		(0x04)
55		measurement data	fHumRoom4	present value room humidity 4	R	%rH	0.1	int		32788		(0x04)
56		measurement data	fHumRoom5	present value room humidity 5	R	%rH	0.1	int		32789		(0x04)
57		measurement data	fHumRoomMean	mean value of all room humidities	R	%rH	0.1	int		32790		(0x04)
58	S	measurement data	fTempODA	present value outdoor air temperature	R	°C	0.1	int		32791		(0x04)
59	S	measurement data	fTempSUP	present value supply air temperature	R	°C	0.1	int		32792		(0x04)
60	S	measurement data	fTempETA	present value extracted air temperature	R	°C	0.1	int		32793		(0x04)
61	S	measurement data	fTempEHA	present value exhaust air temperature	R	°C	0.1	int		32794		(0x04)
62	S	measurement data	fHumODA	present value outdoor air humidity	R	%rH	0.1	uint		32795		(0x04)
63	S	measurement data	fHumSUP	present value supply air humidity	R	%rH	0.1	uint		32796		(0x04)
64	S	measurement data	fHumETA	present value extracted air humidity	R	%rH	0.1	uint		32797		(0x04)
65	S	measurement data	fHumEHA	present value exhaust air humidity	R	%rH	0.1	uint		32798		(0x04)
66	S	measurement data	fPressureSUP	present value supply duct pressure	R	Pa		uint		32799		(0x04)
67	S	measurement data	fPressureETA	present value exhaust duct pressure	R	Pa		uint		32800		(0x04)
68	S	measurement data	fVOC	present value voc concentration	R	ppm		uint		32801		(0x04)
69	S	measurement data	fCO2	present value CO2 concentration	R	ppm		uint		32802		(0x04)
70		measurement data	fTempRoom1	present value room temperature 1	R	°C	0.1	int		32803		(0x04)
71		measurement data	fTempRoom2	present value room temperature 2	R	°C	0.1	int		32804		(0x04)
72		measurement data	fTempRoom3	present value room temperature 3	R	°C	0.1	int		32805		(0x04)
73		measurement data	fTempRoom4	present value room temperature 4	R	°C	0.1	int		32806		(0x04)
74		measurement data	fTempRoom5	present value room temperature 5	R	°C	0.1	int		32807		(0x04)
75		measurement data	fTempRoom6	present value room temperature 6	R	°C	0.1	int		32808		(0x04)
76		measurement data	fTempRoom7	present value room temperature 7	R	°C	0.1	int		32809		(0x04)
77		measurement data	fTempRoom8	present value room temperature 8	R	°C	0.1	int		32810		(0x04)
78		measurement data	fTempRoomMean	mean value of all room temperatures	R	°C	0.1	int		32812		(0x04)
79	S	cooler	bCoolStateMotorProtection	error motor protection cooler pump	R			bool	TRUE = ok	32813	0	(0x04)
80		cooler	bCoolStateErrModbusValve	modbus comm. error with the cooler valve	R			bool	TRUE = ok	32813	1	(0x04)
81	S	cooler	bCoolCtrlPump	controlled value to switch on/off the cooler pump	R			bool	TRUE = on	32813	2	(0x04)
82	S	cooler	fCoolStateValve	current position of the cooler valve	R	%		uint		32814		(0x04)
83	S	cooler	fCoolMeaInletTemp	present value of the cooler inlet temperature	R	°C	0.1	int		32815		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
84		cooler	fCoolCtrlValve	controlled value of the cooler valve	R	%		uint		32816		(0x04)
85	S	preheater	bPreHeatStateMotorProtection	error motor protection preheater pump	R			bool	TRUE = ok	32822	0	(0x04)
86		preheater	bPreHeatStateErrModbusValve	modbus comm. error with the preheater valve	R			bool	TRUE = ok	32822	1	(0x04)
87	S	preheater	bPreHeatCtrlPump	controlled value to switch on/off the preheater pump	R			bool	TRUE = on	32822	2	(0x04)
88	S	preheater	fPreHeatStateValve	current position of the preheater valve	R	%		uint		32823		(0x04)
89	S	preheater	fPreHeatMeaReturnTemp	present value of the preheater outlet temperature	R	°C	0.1	int		32824		(0x04)
90		preheater	fPreHeatCtrlValve	controlled value of the preheater valve	R	%		uint		32825		(0x04)
91	S	reheater	bReHeatStateMotorProtection	error motor protection reheat pump	R			bool	TRUE = ok	32831	0	(0x04)
92		reheater	bReHeatStateErrModbusValve	modbus comm. error with the reheat valve	R			bool	TRUE = ok	32831	1	(0x04)
93	S	reheater	bReHeatCtrlPump	controlled value to switch on/off the reheat pump	R			bool	TRUE = on	32831	2	(0x04)
94	S	reheater	fReHeatStateValve	current position of the reheat valve	R	%		uint		32832		(0x04)
95	S	reheater	fReHeatMeaReturnTemp	present value of the reheat outlet temperature	R	°C	0.1	int		32833		(0x04)
96		reheater	fReHeatCtrlValve	controlled value of the reheat valve	R	%		uint		32834		(0x04)
97		damper	bDamperStateErrModbusODA	modbus comm. error with the outdoor air damper	R			bool	TRUE = ok	32840	0	(0x04)
98		damper	bDamperStateErrModbusSUP	modbus comm. error with the supply air damper	R			bool	TRUE = ok	32840	1	(0x04)
99		damper	bDamperStateErrModbusETA	modbus comm. error with the extracted air damper	R			bool	TRUE = ok	32840	2	(0x04)
100		damper	bDamperStateErrModbusEHA	modbus comm. error with the exhaust air damper	R			bool	TRUE = ok	32840	3	(0x04)
101		damper	bDamperStateErrModbusRCA	modbus comm. error with the recovery air damper	R			bool	TRUE = ok	32840	4	(0x04)
102		damper	bDamperStateErrModbusODA2	modbus comm. error with the second outdoor air damper	R			bool	TRUE = ok	32840	5	(0x04)
103		damper	bDamperStateErrModbusSUP2	modbus comm. error with the second supply air damper	R			bool	TRUE = ok	32840	6	(0x04)
104		damper	bDamperStateErrModbusETA2	modbus comm. error with the second extracted air damper	R			bool	TRUE = ok	32840	7	(0x04)
105		damper	bDamperStateErrModbusEHA2	modbus comm. error with the second exhaust air damper	R			bool	TRUE = ok	32840	8	(0x04)
106		damper	bDamperStateErrModbusRCA2	modbus comm. error with the second recovery air damper	R			bool	TRUE = ok	32840	9	(0x04)
107		damper	bDamperStateErrModbusFanSUP	modbus comm. error with the supply air fan damper	R			bool	TRUE = ok	32840	10	(0x04)
108		damper	bDamperStateErrModbusFanETA	modbus comm. error with the extracted air fan damper	R			bool	TRUE = ok	32840	11	(0x04)
109		damper	bDamperStateErrModbusFanSUP2	modbus comm. error with the second supply air fan damper	R			bool	TRUE = ok	32840	12	(0x04)
110		damper	bDamperStateErrModbusFanETA2	modbus comm. error with the second extracted air fan damper	R			bool	TRUE = ok	32840	13	(0x04)
111	S	damper	fDamperStateODA	current position of the outdoor air damper	R	%		uint		32842		(0x04)
112	S	damper	fDamperStateSUP	current position of the supply air damper	R	%		uint		32843		(0x04)
113	S	damper	fDamperStateETA	current position of the extract air damper	R	%		uint		32844		(0x04)
114	S	damper	fDamperStateEHA	current position of the exhaust air damper	R	%		uint		32845		(0x04)
115	S	damper	fDamperStateRCA	current position of the recovery air damper	R	%		uint		32846		(0x04)
116		damper	fDamperStateODA2	current position of the second outdoor air damper	R	%		uint		32847		(0x04)
117		damper	fDamperStateSUP2	current position of the second supply air damper	R	%		uint		32848		(0x04)
118		damper	fDamperStateETA2	current position of the second extract air damper	R	%		uint		32849		(0x04)
119		damper	fDamperStateEHA2	current position of the second exhaust air damper	R	%		uint		32850		(0x04)
120		damper	fDamperStateRCA2	current position of the second recovery air damper	R	%		uint		32851		(0x04)
121		damper	fDamperStateFanSUP	current position of the supply air fan damper	R	%		uint		32852		(0x04)
122		damper	fDamperStateFanETA	current position of the extract air fan damper	R	%		uint		32853		(0x04)
123		damper	fDamperStateFanSUP2	current position of the second supply air fan damper	R	%		uint		32854		(0x04)
124		damper	fDamperStateFanETA2	current position of the second extract air fan damper	R	%		uint		32855		(0x04)
125	S	damper	fDamperCtrlODA	controlled value of the outdoor air damper position	R	%		uint		32856		(0x04)
126	S	damper	fDamperCtrlSUP	controlled value of the supply air damper position	R	%		uint		32857		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
127	S	damper	fDamperCtrlETA	controlled value of the extract air damper position	R	%		uint		32858		(0x04)
128	S	damper	fDamperCtrlEHA	controlled value of the exhaust air damper position	R	%		uint		32859		(0x04)
129	S	damper	fDamperCtrlRCA	controlled value of the recovery air damper position	R	%		uint		32860		(0x04)
130		damper	fDamperCtrlODA2	controlled value of the second outdoor air damper position	R	%		uint		32861		(0x04)
131		damper	fDamperCtrlSUP2	controlled value of the second supply air damper position	R	%		uint		32862		(0x04)
132		damper	fDamperCtrlETA2	controlled value of the second extract air damper position	R	%		uint		32863		(0x04)
133		damper	fDamperCtrlEHA2	controlled value of the second exhaust air damper position	R	%		uint		32864		(0x04)
134		damper	fDamperCtrlRCA2	controlled value of the second recovery air damper position	R	%		uint		32865		(0x04)
135		damper	fDamperCtrlFanSUP	controlled value of the supply air fan damper position	R	%		uint		32866		(0x04)
136		damper	fDamperCtrlFanETA	controlled value of the extract air fan damper position	R	%		uint		32867		(0x04)
137		damper	fDamperCtrlFanSUP2	controlled value of the second supply air fan damper position	R	%		uint		32868		(0x04)
138		damper	fDamperCtrlFanETA2	controlled value of the second extract air fan damper position	R	%		uint		32869		(0x04)
139		supply air fan	bFanStateMotorProtectionSUP	motor protection of the supply air fan is inactive	R			bool	TRUE = ok	32871	0	(0x04)
140		supply air fan	bFanStateRepairSwitchSUP	repair switch of the supply air fan is active	R			bool	TRUE = ok	32871	1	(0x04)
141	S	supply air fan	bFanStateErrorSUP	internal error of the supply air fan	R			bool	TRUE = ok	32871	2	(0x04)
142		supply air fan	bFanStateErrModbusFuSUP	modbus comm. error with the supply air fan	R			bool	TRUE = ok	32871	3	(0x04)
143		supply air fan	bFanStateErrModbusDpSUP	modbus comm. error with the pressure transmitter of the supply air fan	R			bool	TRUE = ok	32871	4	(0x04)
144	S	supply air fan	bFanCtrlOperationSUP	controlled value to switch on/off the supply air fan	R			bool	TRUE = on	32871	5	(0x04)
145		supply air fan	bFanStateMotorProtectionSUP2	motor protection of the second supply air fan is inactive	R			bool	TRUE = ok	32871	6	(0x04)
146		supply air fan	bFanStateRepairSwitchSUP2	repair switch of the second supply air fan is active	R			bool	TRUE = ok	32871	7	(0x04)
147		supply air fan	bFanStateErrorSUP2	internal error of the second supply air fan	R			bool	TRUE = ok	32871	8	(0x04)
148		supply air fan	bFanStateErrModbusFuSUP2	modbus comm. error with the second supply air fan	R			bool	TRUE = ok	32871	9	(0x04)
149		supply air fan	bFanStateErrModbusDpSUP2	modbus comm. error with the pressure transmitter of the second supply air fan	R			bool	TRUE = ok	32871	10	(0x04)
150		supply air fan	bFanCtrlOperationSUP2	controlled value to switch on/off the second supply air fan	R			bool	TRUE = on	32871	11	(0x04)
151	S	supply air fan	fFanCtrlSpeedSUP	controlled value of the supply air fan speed [0..100%]	R	%		uint		32873		(0x04)
152	S	supply air fan	fFanMeaDpSUP	present value supply air fan diff. pressure	R	Pa		uint		32874		(0x04)
153	S	supply air fan	fFanMeaAirFlowSUP	present value supply airflow	R	m³/h		uint		32875		(0x04)
154		supply air fan	fFanCtrlSpeedSUP2	controlled value of the second supply air fan speed [0..100%]	R	%		uint		32876		(0x04)
155		supply air fan	fFanMeaDpSUP2	present value second supply air fan diff. pressure	R	Pa		uint		32877		(0x04)
156		supply air fan	fFanMeaAirFlowSUP2	present value second supply airflow	R	m³/h		uint		32878		(0x04)
157		extract air fan	bFanStateMotorProtectionETA	motor protection of the extract air fan is inactive	R			bool	TRUE = ok	32881	0	(0x04)
158		extract air fan	bFanStateRepairSwitchETA	repair switch of the extract air fan is active	R			bool	TRUE = ok	32881	1	(0x04)
159	S	extract air fan	bFanStateErrorETA	internal error of the extract air fan	R			bool	TRUE = ok	32881	2	(0x04)
160		extract air fan	bFanStateErrModbusFuETA	modbus comm. error with the extract air fan	R			bool	TRUE = ok	32881	3	(0x04)
161		extract air fan	bFanStateErrModbusDpETA	modbus comm. error with the pressure transmitter of the extract air fan	R			bool	TRUE = ok	32881	4	(0x04)
162	S	extract air fan	bFanCtrlOperationETA	controlled value to switch on/off the extract air fan	R			bool	TRUE = on	32881	5	(0x04)
163		extract air fan	bFanStateMotorProtectionETA2	motor protection of the second extract air fan is inactive	R			bool	TRUE = ok	32881	6	(0x04)
164		extract air fan	bFanStateRepairSwitchETA2	repair switch of the second extract air fan is active	R			bool	TRUE = ok	32881	7	(0x04)
165		extract air fan	bFanStateErrorETA2	internal error of the second extract air fan	R			bool	TRUE = ok	32881	8	(0x04)
166		extract air fan	bFanStateErrModbusFuETA2	modbus comm. error with the second extract air fan	R			bool	TRUE = ok	32881	9	(0x04)
167		extract air fan	bFanStateErrModbusDpETA2	modbus comm. error with the pressure transmitter of the second extract air fan	R			bool	TRUE = ok	32881	10	(0x04)
168		extract air fan	bFanCtrlOperationETA2	controlled value to switch on/off the second extract air fan	R			bool	TRUE = on	32881	11	(0x04)
169	S	extract air fan	fFanCtrlSpeedETA	controlled value of the extract air fan speed [0..100%]	R	%		uint		32883		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
170	S	extract air fan	fFanMeaDpETA	present value extract air fan diff. pressure	R	Pa		uint		32884		(0x04)
171	S	extract air fan	fFanMeaAirFlowETA	present value extract airflow	R	m³/h		uint		32885		(0x04)
172		extract air fan	fFanCtrlSpeedETA2	controlled value of the second extract air fan speed [0..100%]	R	%		uint		32886		(0x04)
173		extract air fan	fFanMeaDpETA2	present value second extract air fan diff. pressure	R	Pa		uint		32887		(0x04)
174		extract air fan	fFanMeaAirFlowETA2	present value second extract airflow	R	m³/h		uint		32888		(0x04)
175	S	filter	bFilterStateWarningODA	error outdoor air filter change required	R			bool	TRUE = ok	32891	0	(0x04)
176	S	filter	bFilterStateWarningSUP	error supply air filter change required	R			bool	TRUE = ok	32891	1	(0x04)
177	S	filter	bFilterStateWarningETA	error extract air filter change required	R			bool	TRUE = ok	32891	2	(0x04)
178		filter	bFilterStateErrModbusDpODA	comm. error pressure sensor outdoor air filter	R			bool	TRUE = ok	32891	3	(0x04)
179		filter	bFilterStateErrModbusDpSUP	comm. error pressure sensor supply air filter	R			bool	TRUE = ok	32891	4	(0x04)
180		filter	bFilterStateErrModbusDpETA	comm. error pressure sensor extract air filter	R			bool	TRUE = ok	32891	5	(0x04)
181		filter	bFilterStateWarningODA2	error second outdoor air filter change required	R			bool	TRUE = ok	32891	6	(0x04)
182		filter	bFilterStateWarningSUP2	error second supply air filter change required	R			bool	TRUE = ok	32891	7	(0x04)
183		filter	bFilterStateWarningETA2	error second extract air filter change required	R			bool	TRUE = ok	32891	8	(0x04)
184		filter	bFilterStateErrModbusDpODA2	comm. error pressure sensor second outdoor air filter	R			bool	TRUE = ok	32891	9	(0x04)
185		filter	bFilterStateErrModbusDpSUP2	comm. error pressure sensor second supply air filter	R			bool	TRUE = ok	32891	10	(0x04)
186		filter	bFilterStateErrModbusDpETA2	comm. error pressure sensor second extract air filter	R			bool	TRUE = ok	32891	11	(0x04)
187	S	filter	uiFilterStateHoldingTimeODA	holding time outdoor air filter (in hour)	R	h		uint		32893		(0x04)
188	S	filter	uiFilterStateHoldingTimeSUP	holding time supply air filter (in hour)	R	h		uint		32894		(0x04)
189	S	filter	uiFilterStateHoldingTimeETA	holding time extract air filter (in hour)	R	h		uint		32895		(0x04)
190		filter	uiFilterStateOperatingTimeODA	operation time outdoor air filter (in hour)	R	h		uint		32896		(0x04)
191		filter	uiFilterStateOperatingTimeSUP	operation time supply air filter (in hour)	R	h		uint		32897		(0x04)
192		filter	uiFilterStateOperatingTimeETA	operation time extract air filter (in hour)	R	h		uint		32898		(0x04)
193	S	filter	fFilterMeaDpODA	present value outdoor air filter diff. pressure	R	Pa		uint		32899		(0x04)
194	S	filter	fFilterMeaDpSUP	present value supply air filter diff. pressure	R	Pa		uint		32900		(0x04)
195	S	filter	fFilterMeaDpETA	present value extract air filter diff. pressure	R	Pa		uint		32901		(0x04)
196		filter	uiFilterStateHoldingTimeODA2	holding time second outdoor air filter (in hour)	R	h		uint		32902		(0x04)
197		filter	uiFilterStateHoldingTimeSUP2	holding time second supply air filter (in hour)	R	h		uint		32903		(0x04)
198		filter	uiFilterStateHoldingTimeETA2	holding time second extract air filter (in hour)	R	h		uint		32904		(0x04)
199		filter	uiFilterStateOperatingTimeODA2	operation time second outdoor air filter (in hour)	R	h		uint		32905		(0x04)
200		filter	uiFilterStateOperatingTimeSUP2	operation time second supply air filter (in hour)	R	h		uint		32906		(0x04)
201		filter	uiFilterStateOperatingTimeETA2	operation time second extract air filter (in hour)	R	h		uint		32907		(0x04)
202		filter	fFilterMeaDpODA2	present value second outdoor air filter diff. pressure	R	Pa		uint		32908		(0x04)
203		filter	fFilterMeaDpSUP2	present value second supply air filter diff. pressure	R	Pa		uint		32909		(0x04)
204		filter	fFilterMeaDpETA2	present value second extract air filter diff. pressure	R	Pa		uint		32910		(0x04)
205		plate heat exchanger	bPlaHexStateErrModbusBypass	modbus comm. error with the plate heat exchanger dampe	R			bool	TRUE = ok	32911	0	(0x04)
206		plate heat exchanger	bPlaHexStateErrModbusBypass2	modbus comm. error with the second plate heat exchanger dampe	R			bool	TRUE = ok	32911	1	(0x04)
207		plate heat exchanger	bPlaHexStateErrModbusDp	modbus comm. error with the plate heat exchanger diff. pressure sensor	R			bool	TRUE = ok	32911	2	(0x04)
208	S	plate heat exchanger	fPlaHexStateBypass	current position bypass plate heat exchanger	R	%		uint		32912		(0x04)
209		plate heat exchanger	fPlaHexStateBypass2	current position second bypass plate heat exchanger	R	%		uint		32913		(0x04)
210		plate heat exchanger	fPlaHexMeaTemp	present value recovery air temperature	R	°C	0.1	int		32914		(0x04)
211	S	plate heat exchanger	fPlaHexMeaDp	present value plate heat exchanger diff. pressure	R	%		uint		32915		(0x04)
212	S	plate heat exchanger	fPlaHexCtrlBypass	controlled value bypass plate heat exchanger	R	%		uint		32916		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
213		plate heat exchanger	fPlaHexCtrlBypass2	controlled value of the second bypass plate heat exchanger	R	%		uint		32917		(0x04)
214		rotary heat exchanger	bRotHexStateRotationAlarm	internal error of the heat recovery wheel	R			bool	TRUE = ok	32922	0	(0x04)
215		rotary heat exchanger	bRotHexStateErrModbus	modbus comm. error with the heat recovery wheel	R			bool	TRUE = ok	32922	1	(0x04)
216	S	rotary heat exchanger	bRotHexCtrlOperation	controlled value to release the heat recovery wheel	R			bool	TRUE = ok	32922	2	(0x04)
217	S	rotary heat exchanger	fRotHexCtrlRPM	controlled value heat recovery wheel speed	R	%		uint		32923		(0x04)
218		modbus comm. error	bModErrHumODA	modbus comm. error with the outdoor air humidity sensor	R			bool	TRUE = ok	32929	0	(0x04)
219		modbus comm. error	bModErrHumSUP	modbus comm. error with the supply air humidity sensor	R			bool	TRUE = ok	32929	1	(0x04)
220		modbus comm. error	bModErrHumETA	modbus comm. error with the extract air humidity sensor	R			bool	TRUE = ok	32929	2	(0x04)
221		modbus comm. error	bModErrHumEHA	modbus comm. error with the exhaust air humidity sensor	R			bool	TRUE = ok	32929	3	(0x04)
222		modbus comm. error	bModErrTempODA	modbus comm. error with the outdoor air temperature sensor	R			bool	TRUE = ok	32929	4	(0x04)
223		modbus comm. error	bModErrTempSUP	modbus comm. error with the supply air temperature sensor	R			bool	TRUE = ok	32929	5	(0x04)
224		modbus comm. error	bModErrTempETA	modbus comm. error with the extract air temperature sensor	R			bool	TRUE = ok	32929	6	(0x04)
225		modbus comm. error	bModErrTempEHA	modbus comm. error with the exhaust air temperature sensor	R			bool	TRUE = ok	32929	7	(0x04)
226		modbus comm. error	bModErrDpSUP	modbus comm. error with the supply air pressure sensor	R			bool	TRUE = ok	32929	8	(0x04)
227		modbus comm. error	bModErrDpETA	modbus comm. error with the extract air pressure sensor	R			bool	TRUE = ok	32929	9	(0x04)
228		modbus comm. error	bModErrCO2	modbus comm. error with the CO2 sensor	R			bool	TRUE = ok	32929	10	(0x04)
229		modbus comm. error	bModErrVOC	modbus comm. error with the VOC sensor	R			bool	TRUE = ok	32929	11	(0x04)
230		modbus comm. error	bModErrTempRoom1	modbus comm. error with the room temperature sensor 1	R			bool	TRUE = ok	32930	0	(0x04)
231		modbus comm. error	bModErrTempRoom2	modbus comm. error with the room temperature sensor 2	R			bool	TRUE = ok	32930	1	(0x04)
232		modbus comm. error	bModErrTempRoom3	modbus comm. error with the room temperature sensor 3	R			bool	TRUE = ok	32930	2	(0x04)
233		modbus comm. error	bModErrTempRoom4	modbus comm. error with the room temperature sensor 4	R			bool	TRUE = ok	32930	3	(0x04)
234		modbus comm. error	bModErrTempRoom5	modbus comm. error with the room temperature sensor 5	R			bool	TRUE = ok	32930	4	(0x04)
235		modbus comm. error	bModErrHumRoom1	modbus comm. error with the room humidity sensor 1	R			bool	TRUE = ok	32930	5	(0x04)
236		modbus comm. error	bModErrHumRoom2	modbus comm. error with the room humidity sensor 2	R			bool	TRUE = ok	32930	6	(0x04)
237		modbus comm. error	bModErrHumRoom3	modbus comm. error with the room humidity sensor 3	R			bool	TRUE = ok	32930	7	(0x04)
238		modbus comm. error	bModErrHumRoom4	modbus comm. error with the room humidity sensor 4	R			bool	TRUE = ok	32930	8	(0x04)
239		modbus comm. error	bModErrHumRoom5	modbus comm. error with the room humidity sensor 5	R			bool	TRUE = ok	32930	9	(0x04)
240		current operation mode	fSetpointTempSUP	current set point of the supply air temperature	R	°C	0.1	int		32940		(0x04)
241		current operation mode	fSetpointTempETA	current set point of the extract or room air temperature	R	°C	0.1	int		32941		(0x04)
242	S	current operation mode	eOperationMode	current operation mode of the air handling unit.	R			uint	0 = off; 1 = standby; 2 = control; 3 = freeze protection; 4 = deicing; 5 = startup; 6 = shutdown; 7 = manual; 8 = nightpurge; 9 = intermittent Operation; 10 = cooling protection; 11 = fire protection	32942		(0x04)
243		current operation mode	fFanPowerSUP1	electrical power supply fan 1	R	kW	0.01	uint		32943		(0x04)
244		current operation mode	fFanPowerSUP2	electrical power supply fan 2	R	kW	0.01	uint		32944		(0x04)
245		current operation mode	fFanPowerETA1	electrical power extract fan 1	R	kW	0.01	uint		32945		(0x04)
246		current operation mode	fFanPowerETA2	electrical power extract fan 2	R	kW	0.01	uint		32946		(0x04)
247		current operation mode	fFanSfpSUP1	specific fan power supply fan 1	R	Ws/m³		uint		32947		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
248		current operation mode	<i>fFanSfpETA1</i>	<i>specific fan power extract fan 1</i>	R	Ws/m ³		uint		32949		(0x04)
249		rac	bReleasePump	pump release	R			bool	TRUE = on	32960	0	(0x04)
250		rac	bPumpError	pump error	R			bool	TRUE = alarm	32960	1	(0x04)
251		rac	bBrinePressure1	pressure step 1 triggered	R			bool	TRUE = alarm	32960	2	(0x04)
252		rac	bBrinePressure2	pressure step 2 triggered	R			bool	TRUE = alarm	32960	3	(0x04)
253		rac	bMsgMinTempInletETA	exhaust air heat exchanger is frosting (prio=2)	R			bool	TRUE = alarm	32960	4	(0x04)
254		rac	<i>bMsgPumpError</i>	<i>pump error (prio=3)</i>	R			bool	<i>TRUE = alarm</i>	32960	5	(0x04)
255		rac	bMsgFrostFeedCoil	alarm feed coil frosting (prio=3)	R			bool	TRUE = alarm	32960	6	(0x04)
256		rac	bMsgNoRecovery	heat recovery is currently not possible (prio=2)	R			bool	TRUE = alarm	32960	7	(0x04)
257		rac	bMsgNoFeed	feed doesn't have cooling or heating (prio=2)	R			bool	TRUE = alarm	32960	8	(0x04)
258		rac	<i>bMsgPumpMinVolumeFlow</i>	<i>min. pump volume flow (prio=3)</i>	R			bool	<i>TRUE = alarm</i>	32960	9	(0x04)
259		rac	bMsgBrinePressureLow	brine pressure have to be checked, low pressure (prio=2)	R			bool	TRUE = alarm	32960	10	(0x04)
260		rac	bMsgBrinePressureCritical	critical brine pressure (prio=3)	R			bool	TRUE = alarm	32960	11	(0x04)
261		rac	bMsgAutoPumpOff	auto pump stop (prio=2)	R			bool	TRUE = alarm	32960	12	(0x04)
262		rac	bStateHeatExchangerOperation	state of the operation signal be released	R			bool	TRUE = on	32960	13	(0x04)
263		rac	bStateFastMode	state of the fast cool- or heating mode active	R			bool	TRUE = on	32960	14	(0x04)
264		rac	bStateCoolingFeed	state of the cooling feed feeding is active	R			bool	TRUE = on	32960	15	(0x04)
265		rac	bStateHeatingFeed	state of the heating feed feeding is active	R			bool	TRUE = on	32961	0	(0x04)
266		rac	<i>bMsgPumpWarning</i>	<i>pump error outputted a warning signal (prio=2)</i>	R			bool	<i>TRUE = alarm</i>	32961	1	(0x04)
267		rac	bActuatingValueFeedCoolingPump	pump release cooling feed	R			bool	TRUE = on	32961	2	(0x04)
268		rac	bActuatingValueFeedHeatingPump	pump release heating feed	R			bool	TRUE = on	32961	3	(0x04)
269		rac	bReleaseColdProvider	release cold provider	R			bool	TRUE = on	32961	4	(0x04)
270		rac	bReleaseHeatProvider	release heat provider	R			bool	TRUE = on	32961	5	(0x04)
271		rac	rActuatingValuePump	controlled value pump speed	R	%		uint		32962		(0x04)
272		rac	rActuatingValuePowerValve	controlled value run around coil power valve	R	%		uint		32963		(0x04)
273		rac	rActuatingValueFrostProtectionValve	controlled value run around coil frost protection valve	R	%		uint		32964		(0x04)
274		rac	rTempSUPIn	current value inlet temperature of the fresh air heat exchanger	R	°C	0.1	int		32965		(0x04)
275		rac	rTempSUPOut	current value outlet temperature of the fresh air heat exchanger	R	°C	0.1	int		32966		(0x04)
276		rac	rTempETAIn	current value inlet temperature of exhaust air heat exchanger	R	°C	0.1	int		32967		(0x04)
277		rac	rTempETAOOut	current value return temperature exhaust air heat exchanger	R	°C	0.1	int		32968		(0x04)
278		rac	rTempPreFeed	current value brine temperature	R	°C	0.1	int		32969		(0x04)
279		rac	rBrineVolumeFlow	present value brine volume flow	R	m ³ /h	0.01	uint		32970		(0x04)
280		rac	rThermalPowerSUP	current value thermal power of the fresh air heat exchanger	R	kW		int		32971		(0x04)
281		rac	rThermalPowerETA	current value thermal power of the exhaust air heat exchanger	R	kW		int		32972		(0x04)
282		rac	rThermalPowerFeedHeat	current value thermal power of the heating feed	R	kW		int		32973		(0x04)
283		rac	rThermalPowerFeedCool	current value thermal power of the cooling feed	R	kW		int		32974		(0x04)
284		rac	rActuatingValueFeedCoolingValve	controlled value run around coil cooling feed valve	R	%		uint		32975		(0x04)
285		rac	rActuatingValueFeedHeatingValve	controlled value run around coil heating feed valve	R	%		uint		32976		(0x04)
286		rac	rTempCoolFeedIn	current value inlet temperature of cooling feed	R	°C	0.1	int		32977		(0x04)
287		rac	rTempHeatFeedOut	current value return temperature of heating feed	R	°C	0.1	int		32978		(0x04)
288		rac	rActuatingValueDehumCoolValve	controlled value run around coil dehumidifier cooling valve	R	%		uint		32979		(0x04)
289		rac	rActuatingValueDehumReaheater	controlled value run around coil dehumidifier cooling recovery valve	R	%		uint		32980		(0x04)
290		integrated refrigerating	bMsgErrorSuperHeatingController	error super heating controller	R			bool	TRUE = alarm	32985	0	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
291		integrated refrigerating	bMsgOilManagement	oil management error	R			bool	TRUE = alarm	32985	1	(0x04)
292		integrated refrigerating	bMsgHighPressure	high pressure error	R			bool	TRUE = alarm	32985	2	(0x04)
293		integrated refrigerating	bMsgLowPressure	low pressure error	R			bool	TRUE = alarm	32985	3	(0x04)
294		integrated refrigerating	bCompressorPWM [1]	actuating value pwm compressor 1	R			bool	TRUE = on	32985	4	(0x04)
295		integrated refrigerating	bCompressorPWM [2]	actuating value pwm compressor 2	R			bool	TRUE = on	32985	5	(0x04)
296		integrated refrigerating	arCompMotorProtection [1]	motor protection triggered first compressor	R			bool	TRUE = alarm	32985	7	(0x04)
297		integrated refrigerating	arCompMotorProtection [2]	motor protection triggered second compressor	R			bool	TRUE = alarm	32985	8	(0x04)
298		integrated refrigerating	arSoftStarterOn [1]	actuating value soft starter compressor 1	R			bool	TRUE = on	32985	10	(0x04)
299		integrated refrigerating	arSoftStarterOn [2]	actuating value soft starter compressor 2	R			bool	TRUE = on	32985	11	(0x04)
300		integrated refrigerating	bMsgHighTemp	error - high compressor end temperature	R			bool	TRUE = alarm	32985	13	(0x04)
301		integrated refrigerating	bEAPComError	comm. error with the EAP-Modul	R			bool	TRUE = alarm	32985	14	(0x04)
302	S	fire damper	bCriticalSmokeDetectorOrFireDampe	collective fault of smoke detectors and fire dampers	R			bool	TRUE = alarm	32990	0	(0x04)
303	S	fire damper	bFireDampersOK	all fire dampers are ok	R			bool	TRUE = ok	32990	1	(0x04)
304	S	fire damper	bSmokeDetectorsOK	all smoke detectors are ok	R			bool	TRUE = ok	32990	2	(0x04)
305		fire damper	bFireDamperClosed1	contact fire damper 1 closed	R			bool	TRUE = closed	32991	0	(0x04)
306		fire damper	bFireDamperClosed2	contact fire damper 2 closed	R			bool	TRUE = closed	32991	1	(0x04)
307		fire damper	bFireDamperClosed3	contact fire damper 3 closed	R			bool	TRUE = closed	32991	2	(0x04)
308		fire damper	bFireDamperClosed4	contact fire damper 4 closed	R			bool	TRUE = closed	32991	3	(0x04)
309		fire damper	bFireDamperClosed5	contact fire damper 5 closed	R			bool	TRUE = closed	32991	4	(0x04)
310		fire damper	bFireDamperClosed6	contact fire damper 6 closed	R			bool	TRUE = closed	32991	5	(0x04)
311		fire damper	bFireDamperClosed7	contact fire damper 7 closed	R			bool	TRUE = closed	32991	6	(0x04)
312		fire damper	bFireDamperClosed8	contact fire damper 8 closed	R			bool	TRUE = closed	32991	7	(0x04)
313		fire damper	bFireDamperClosed9	contact fire damper 9 closed	R			bool	TRUE = closed	32991	8	(0x04)
314		fire damper	bFireDamperClosed10	contact fire damper 10 closed	R			bool	TRUE = closed	32991	9	(0x04)
315		fire damper	bFireDamperClosed11	contact fire damper 11 closed	R			bool	TRUE = closed	32991	10	(0x04)
316		fire damper	bFireDamperClosed12	contact fire damper 12 closed	R			bool	TRUE = closed	32991	11	(0x04)
317		fire damper	bFireDamperClosed13	contact fire damper 13 closed	R			bool	TRUE = closed	32991	12	(0x04)
318		fire damper	bFireDamperClosed14	contact fire damper 14 closed	R			bool	TRUE = closed	32991	13	(0x04)
319		fire damper	bFireDamperClosed15	contact fire damper 15 closed	R			bool	TRUE = closed	32991	14	(0x04)
320		fire damper	bFireDamperClosed16	contact fire damper 16 closed	R			bool	TRUE = closed	32991	15	(0x04)
321		fire damper	bFireDamperClosed17	contact fire damper 17 closed	R			bool	TRUE = closed	32992	0	(0x04)
322		fire damper	bFireDamperClosed18	contact fire damper 18 closed	R			bool	TRUE = closed	32992	1	(0x04)
323		fire damper	bFireDamperClosed19	contact fire damper 19 closed	R			bool	TRUE = closed	32992	2	(0x04)
324		fire damper	bFireDamperClosed20	contact fire damper 20 closed	R			bool	TRUE = closed	32992	3	(0x04)
325		fire damper	bFireDamperClosed21	contact fire damper 21 closed	R			bool	TRUE = closed	32992	4	(0x04)
326		fire damper	bFireDamperClosed22	contact fire damper 22 closed	R			bool	TRUE = closed	32992	5	(0x04)
327		fire damper	bFireDamperClosed23	contact fire damper 23 closed	R			bool	TRUE = closed	32992	6	(0x04)
328		fire damper	bFireDamperClosed24	contact fire damper 24 closed	R			bool	TRUE = closed	32992	7	(0x04)
329		fire damper	bFireDamperClosed25	contact fire damper 25 closed	R			bool	TRUE = closed	32992	8	(0x04)
330		fire damper	bFireDamperClosed26	contact fire damper 26 closed	R			bool	TRUE = closed	32992	9	(0x04)
331		fire damper	bFireDamperClosed27	contact fire damper 27 closed	R			bool	TRUE = closed	32992	10	(0x04)
332		fire damper	bFireDamperClosed28	contact fire damper 28 closed	R			bool	TRUE = closed	32992	11	(0x04)
333		fire damper	bFireDamperClosed29	contact fire damper 29 closed	R			bool	TRUE = closed	32992	12	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
334		fire damper	bFireDamperClosed30	contact fire damper 30 closed	R			bool	TRUE = closed	32992	13	(0x04)
335		fire damper	bFireDamperClosed31	contact fire damper 31 closed	R			bool	TRUE = closed	32992	14	(0x04)
336		fire damper	bFireDamperClosed32	contact fire damper 32 closed	R			bool	TRUE = closed	32992	15	(0x04)
337		fire damper	bFireDamperClosed33	contact fire damper 33 closed	R			bool	TRUE = closed	32993	0	(0x04)
338		fire damper	bFireDamperClosed34	contact fire damper 34 closed	R			bool	TRUE = closed	32993	1	(0x04)
339		fire damper	bFireDamperClosed35	contact fire damper 35 closed	R			bool	TRUE = closed	32993	2	(0x04)
340		fire damper	bFireDamperClosed36	contact fire damper 36 closed	R			bool	TRUE = closed	32993	3	(0x04)
341		fire damper	bFireDamperClosed37	contact fire damper 37 closed	R			bool	TRUE = closed	32993	4	(0x04)
342		fire damper	bFireDamperClosed38	contact fire damper 38 closed	R			bool	TRUE = closed	32993	5	(0x04)
343		fire damper	bFireDamperClosed39	contact fire damper 39 closed	R			bool	TRUE = closed	32993	6	(0x04)
344		fire damper	bFireDamperClosed40	contact fire damper 40 closed	R			bool	TRUE = closed	32993	7	(0x04)
345		fire damper	bFireDamperClosed41	contact fire damper 41 closed	R			bool	TRUE = closed	32993	8	(0x04)
346		fire damper	bFireDamperClosed42	contact fire damper 42 closed	R			bool	TRUE = closed	32993	9	(0x04)
347		fire damper	bFireDamperClosed43	contact fire damper 43 closed	R			bool	TRUE = closed	32993	10	(0x04)
348		fire damper	bFireDamperClosed44	contact fire damper 44 closed	R			bool	TRUE = closed	32993	11	(0x04)
349		fire damper	bFireDamperClosed45	contact fire damper 45 closed	R			bool	TRUE = closed	32993	12	(0x04)
350		fire damper	bFireDamperClosed46	contact fire damper 46 closed	R			bool	TRUE = closed	32993	13	(0x04)
351		fire damper	bFireDamperClosed47	contact fire damper 47 closed	R			bool	TRUE = closed	32993	14	(0x04)
352		fire damper	bFireDamperClosed48	contact fire damper 48 closed	R			bool	TRUE = closed	32993	15	(0x04)
353		fire damper	bFireDamperClosed49	contact fire damper 49 closed	R			bool	TRUE = closed	32994	0	(0x04)
354		fire damper	bFireDamperClosed50	contact fire damper 50 closed	R			bool	TRUE = closed	32994	1	(0x04)
355		fire damper	bFireDamperClosed51	contact fire damper 51 closed	R			bool	TRUE = closed	32994	2	(0x04)
356		fire damper	bFireDamperClosed52	contact fire damper 52 closed	R			bool	TRUE = closed	32994	3	(0x04)
357		fire damper	bFireDamperClosed53	contact fire damper 53 closed	R			bool	TRUE = closed	32994	4	(0x04)
358		fire damper	bFireDamperClosed54	contact fire damper 54 closed	R			bool	TRUE = closed	32994	5	(0x04)
359		fire damper	bFireDamperClosed55	contact fire damper 55 closed	R			bool	TRUE = closed	32994	6	(0x04)
360		fire damper	bFireDamperClosed56	contact fire damper 56 closed	R			bool	TRUE = closed	32994	7	(0x04)
361		fire damper	bFireDamperClosed57	contact fire damper 57 closed	R			bool	TRUE = closed	32994	8	(0x04)
362		fire damper	bFireDamperClosed58	contact fire damper 58 closed	R			bool	TRUE = closed	32994	9	(0x04)
363		fire damper	bFireDamperClosed59	contact fire damper 59 closed	R			bool	TRUE = closed	32994	10	(0x04)
364		fire damper	bFireDamperClosed60	contact fire damper 60 closed	R			bool	TRUE = closed	32994	11	(0x04)
365		fire damper	bFireDamperClosed61	contact fire damper 61 closed	R			bool	TRUE = closed	32994	12	(0x04)
366		fire damper	bFireDamperClosed62	contact fire damper 62 closed	R			bool	TRUE = closed	32994	13	(0x04)
367		fire damper	bFireDamperOpened1	contact fire damper 1 Opened	R			bool	TRUE = open	32995	0	(0x04)
368		fire damper	bFireDamperOpened2	contact fire damper 2 Opened	R			bool	TRUE = open	32995	1	(0x04)
369		fire damper	bFireDamperOpened3	contact fire damper 3 Opened	R			bool	TRUE = open	32995	2	(0x04)
370		fire damper	bFireDamperOpened4	contact fire damper 4 Opened	R			bool	TRUE = open	32995	3	(0x04)
371		fire damper	bFireDamperOpened5	contact fire damper 5 Opened	R			bool	TRUE = open	32995	4	(0x04)
372		fire damper	bFireDamperOpened6	contact fire damper 6 Opened	R			bool	TRUE = open	32995	5	(0x04)
373		fire damper	bFireDamperOpened7	contact fire damper 7 Opened	R			bool	TRUE = open	32995	6	(0x04)
374		fire damper	bFireDamperOpened8	contact fire damper 8 Opened	R			bool	TRUE = open	32995	7	(0x04)
375		fire damper	bFireDamperOpened9	contact fire damper 9 Opened	R			bool	TRUE = open	32995	8	(0x04)
376		fire damper	bFireDamperOpened10	contact fire damper 10 Opened	R			bool	TRUE = open	32995	9	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
377		fire damper	bFireDamperOpened11	contact fire damper 11 Opened	R			bool	TRUE = open	32995	10	(0x04)
378		fire damper	bFireDamperOpened12	contact fire damper 12 Opened	R			bool	TRUE = open	32995	11	(0x04)
379		fire damper	bFireDamperOpened13	contact fire damper 13 Opened	R			bool	TRUE = open	32995	12	(0x04)
380		fire damper	bFireDamperOpened14	contact fire damper 14 Opened	R			bool	TRUE = open	32995	13	(0x04)
381		fire damper	bFireDamperOpened15	contact fire damper 15 Opened	R			bool	TRUE = open	32995	14	(0x04)
382		fire damper	bFireDamperOpened16	contact fire damper 16 Opened	R			bool	TRUE = open	32995	15	(0x04)
383		fire damper	bFireDamperOpened17	contact fire damper 17 Opened	R			bool	TRUE = open	32996	0	(0x04)
384		fire damper	bFireDamperOpened18	contact fire damper 18 Opened	R			bool	TRUE = open	32996	1	(0x04)
385		fire damper	bFireDamperOpened19	contact fire damper 19 Opened	R			bool	TRUE = open	32996	2	(0x04)
386		fire damper	bFireDamperOpened20	contact fire damper 20 Opened	R			bool	TRUE = open	32996	3	(0x04)
387		fire damper	bFireDamperOpened21	contact fire damper 21 Opened	R			bool	TRUE = open	32996	4	(0x04)
388		fire damper	bFireDamperOpened22	contact fire damper 22 Opened	R			bool	TRUE = open	32996	5	(0x04)
389		fire damper	bFireDamperOpened23	contact fire damper 23 Opened	R			bool	TRUE = open	32996	6	(0x04)
390		fire damper	bFireDamperOpened24	contact fire damper 24 Opened	R			bool	TRUE = open	32996	7	(0x04)
391		fire damper	bFireDamperOpened25	contact fire damper 25 Opened	R			bool	TRUE = open	32996	8	(0x04)
392		fire damper	bFireDamperOpened26	contact fire damper 26 Opened	R			bool	TRUE = open	32996	9	(0x04)
393		fire damper	bFireDamperOpened27	contact fire damper 27 Opened	R			bool	TRUE = open	32996	10	(0x04)
394		fire damper	bFireDamperOpened28	contact fire damper 28 Opened	R			bool	TRUE = open	32996	11	(0x04)
395		fire damper	bFireDamperOpened29	contact fire damper 29 Opened	R			bool	TRUE = open	32996	12	(0x04)
396		fire damper	bFireDamperOpened30	contact fire damper 30 Opened	R			bool	TRUE = open	32996	13	(0x04)
397		fire damper	bFireDamperOpened31	contact fire damper 31 Opened	R			bool	TRUE = open	32996	14	(0x04)
398		fire damper	bFireDamperOpened32	contact fire damper 32 Opened	R			bool	TRUE = open	32996	15	(0x04)
399		fire damper	bFireDamperOpened33	contact fire damper 33 Opened	R			bool	TRUE = open	32997	0	(0x04)
400		fire damper	bFireDamperOpened34	contact fire damper 34 Opened	R			bool	TRUE = open	32997	1	(0x04)
401		fire damper	bFireDamperOpened35	contact fire damper 35 Opened	R			bool	TRUE = open	32997	2	(0x04)
402		fire damper	bFireDamperOpened36	contact fire damper 36 Opened	R			bool	TRUE = open	32997	3	(0x04)
403		fire damper	bFireDamperOpened37	contact fire damper 37 Opened	R			bool	TRUE = open	32997	4	(0x04)
404		fire damper	bFireDamperOpened38	contact fire damper 38 Opened	R			bool	TRUE = open	32997	5	(0x04)
405		fire damper	bFireDamperOpened39	contact fire damper 39 Opened	R			bool	TRUE = open	32997	6	(0x04)
406		fire damper	bFireDamperOpened40	contact fire damper 40 Opened	R			bool	TRUE = open	32997	7	(0x04)
407		fire damper	bFireDamperOpened41	contact fire damper 41 Opened	R			bool	TRUE = open	32997	8	(0x04)
408		fire damper	bFireDamperOpened42	contact fire damper 42 Opened	R			bool	TRUE = open	32997	9	(0x04)
409		fire damper	bFireDamperOpened43	contact fire damper 43 Opened	R			bool	TRUE = open	32997	10	(0x04)
410		fire damper	bFireDamperOpened44	contact fire damper 44 Opened	R			bool	TRUE = open	32997	11	(0x04)
411		fire damper	bFireDamperOpened45	contact fire damper 45 Opened	R			bool	TRUE = open	32997	12	(0x04)
412		fire damper	bFireDamperOpened46	contact fire damper 46 Opened	R			bool	TRUE = open	32997	13	(0x04)
413		fire damper	bFireDamperOpened47	contact fire damper 47 Opened	R			bool	TRUE = open	32997	14	(0x04)
414		fire damper	bFireDamperOpened48	contact fire damper 48 Opened	R			bool	TRUE = open	32997	15	(0x04)
415		fire damper	bFireDamperOpened49	contact fire damper 49 Opened	R			bool	TRUE = open	32998	0	(0x04)
416		fire damper	bFireDamperOpened50	contact fire damper 50 Opened	R			bool	TRUE = open	32998	1	(0x04)
417		fire damper	bFireDamperOpened51	contact fire damper 51 Opened	R			bool	TRUE = open	32998	2	(0x04)
418		fire damper	bFireDamperOpened52	contact fire damper 52 Opened	R			bool	TRUE = open	32998	3	(0x04)
419		fire damper	bFireDamperOpened53	contact fire damper 53 Opened	R			bool	TRUE = open	32998	4	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
420		fire damper	bFireDamperOpened54	contact fire damper 54 Opened	R			bool	TRUE = open	32998	5	(0x04)
421		fire damper	bFireDamperOpened55	contact fire damper 55 Opened	R			bool	TRUE = open	32998	6	(0x04)
422		fire damper	bFireDamperOpened56	contact fire damper 56 Opened	R			bool	TRUE = open	32998	7	(0x04)
423		fire damper	bFireDamperOpened57	contact fire damper 57 Opened	R			bool	TRUE = open	32998	8	(0x04)
424		fire damper	bFireDamperOpened58	contact fire damper 58 Opened	R			bool	TRUE = open	32998	9	(0x04)
425		fire damper	bFireDamperOpened59	contact fire damper 59 Opened	R			bool	TRUE = open	32998	10	(0x04)
426		fire damper	bFireDamperOpened60	contact fire damper 60 Opened	R			bool	TRUE = open	32998	11	(0x04)
427		fire damper	bFireDamperOpened61	contact fire damper 61 Opened	R			bool	TRUE = open	32998	12	(0x04)
428		fire damper	bFireDamperOpened62	contact fire damper 62 Opened	R			bool	TRUE = open	32998	13	(0x04)
429		fire damper	bFireDamperErrorClosingRuntime1	Error closing runtime fire damper 1	R			bool	TRUE = ok	32999	0	(0x04)
430		fire damper	bFireDamperErrorClosingRuntime2	Error closing runtime fire damper 2	R			bool	TRUE = ok	32999	1	(0x04)
431		fire damper	bFireDamperErrorClosingRuntime3	Error closing runtime fire damper 3	R			bool	TRUE = ok	32999	2	(0x04)
432		fire damper	bFireDamperErrorClosingRuntime4	Error closing runtime fire damper 4	R			bool	TRUE = ok	32999	3	(0x04)
433		fire damper	bFireDamperErrorClosingRuntime5	Error closing runtime fire damper 5	R			bool	TRUE = ok	32999	4	(0x04)
434		fire damper	bFireDamperErrorClosingRuntime6	Error closing runtime fire damper 6	R			bool	TRUE = ok	32999	5	(0x04)
435		fire damper	bFireDamperErrorClosingRuntime7	Error closing runtime fire damper 7	R			bool	TRUE = ok	32999	6	(0x04)
436		fire damper	bFireDamperErrorClosingRuntime8	Error closing runtime fire damper 8	R			bool	TRUE = ok	32999	7	(0x04)
437		fire damper	bFireDamperErrorClosingRuntime9	Error closing runtime fire damper 9	R			bool	TRUE = ok	32999	8	(0x04)
438		fire damper	bFireDamperErrorClosingRuntime10	Error closing runtime fire damper 10	R			bool	TRUE = ok	32999	9	(0x04)
439		fire damper	bFireDamperErrorClosingRuntime11	Error closing runtime fire damper 11	R			bool	TRUE = ok	32999	10	(0x04)
440		fire damper	bFireDamperErrorClosingRuntime12	Error closing runtime fire damper 12	R			bool	TRUE = ok	32999	11	(0x04)
441		fire damper	bFireDamperErrorClosingRuntime13	Error closing runtime fire damper 13	R			bool	TRUE = ok	32999	12	(0x04)
442		fire damper	bFireDamperErrorClosingRuntime14	Error closing runtime fire damper 14	R			bool	TRUE = ok	32999	13	(0x04)
443		fire damper	bFireDamperErrorClosingRuntime15	Error closing runtime fire damper 15	R			bool	TRUE = ok	32999	14	(0x04)
444		fire damper	bFireDamperErrorClosingRuntime16	Error closing runtime fire damper 16	R			bool	TRUE = ok	32999	15	(0x04)
445		fire damper	bFireDamperErrorClosingRuntime17	Error closing runtime fire damper 17	R			bool	TRUE = ok	33000	0	(0x04)
446		fire damper	bFireDamperErrorClosingRuntime18	Error closing runtime fire damper 18	R			bool	TRUE = ok	33000	1	(0x04)
447		fire damper	bFireDamperErrorClosingRuntime19	Error closing runtime fire damper 19	R			bool	TRUE = ok	33000	2	(0x04)
448		fire damper	bFireDamperErrorClosingRuntime20	Error closing runtime fire damper 20	R			bool	TRUE = ok	33000	3	(0x04)
449		fire damper	bFireDamperErrorClosingRuntime21	Error closing runtime fire damper 21	R			bool	TRUE = ok	33000	4	(0x04)
450		fire damper	bFireDamperErrorClosingRuntime22	Error closing runtime fire damper 22	R			bool	TRUE = ok	33000	5	(0x04)
451		fire damper	bFireDamperErrorClosingRuntime23	Error closing runtime fire damper 23	R			bool	TRUE = ok	33000	6	(0x04)
452		fire damper	bFireDamperErrorClosingRuntime24	Error closing runtime fire damper 24	R			bool	TRUE = ok	33000	7	(0x04)
453		fire damper	bFireDamperErrorClosingRuntime25	Error closing runtime fire damper 25	R			bool	TRUE = ok	33000	8	(0x04)
454		fire damper	bFireDamperErrorClosingRuntime26	Error closing runtime fire damper 26	R			bool	TRUE = ok	33000	9	(0x04)
455		fire damper	bFireDamperErrorClosingRuntime27	Error closing runtime fire damper 27	R			bool	TRUE = ok	33000	10	(0x04)
456		fire damper	bFireDamperErrorClosingRuntime28	Error closing runtime fire damper 28	R			bool	TRUE = ok	33000	11	(0x04)
457		fire damper	bFireDamperErrorClosingRuntime29	Error closing runtime fire damper 29	R			bool	TRUE = ok	33000	12	(0x04)
458		fire damper	bFireDamperErrorClosingRuntime30	Error closing runtime fire damper 30	R			bool	TRUE = ok	33000	13	(0x04)
459		fire damper	bFireDamperErrorClosingRuntime31	Error closing runtime fire damper 31	R			bool	TRUE = ok	33000	14	(0x04)
460		fire damper	bFireDamperErrorClosingRuntime32	Error closing runtime fire damper 32	R			bool	TRUE = ok	33000	15	(0x04)
461		fire damper	bFireDamperErrorClosingRuntime33	Error closing runtime fire damper 33	R			bool	TRUE = ok	33001	0	(0x04)
462		fire damper	bFireDamperErrorClosingRuntime34	Error closing runtime fire damper 34	R			bool	TRUE = ok	33001	1	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
463		fire damper	bFireDamperErrorClosingRuntime35	Error closing runtime fire damper 35	R			bool	TRUE = ok	33001	2	(0x04)
464		fire damper	bFireDamperErrorClosingRuntime36	Error closing runtime fire damper 36	R			bool	TRUE = ok	33001	3	(0x04)
465		fire damper	bFireDamperErrorClosingRuntime37	Error closing runtime fire damper 37	R			bool	TRUE = ok	33001	4	(0x04)
466		fire damper	bFireDamperErrorClosingRuntime38	Error closing runtime fire damper 38	R			bool	TRUE = ok	33001	5	(0x04)
467		fire damper	bFireDamperErrorClosingRuntime39	Error closing runtime fire damper 39	R			bool	TRUE = ok	33001	6	(0x04)
468		fire damper	bFireDamperErrorClosingRuntime40	Error closing runtime fire damper 40	R			bool	TRUE = ok	33001	7	(0x04)
469		fire damper	bFireDamperErrorClosingRuntime41	Error closing runtime fire damper 41	R			bool	TRUE = ok	33001	8	(0x04)
470		fire damper	bFireDamperErrorClosingRuntime42	Error closing runtime fire damper 42	R			bool	TRUE = ok	33001	9	(0x04)
471		fire damper	bFireDamperErrorClosingRuntime43	Error closing runtime fire damper 43	R			bool	TRUE = ok	33001	10	(0x04)
472		fire damper	bFireDamperErrorClosingRuntime44	Error closing runtime fire damper 44	R			bool	TRUE = ok	33001	11	(0x04)
473		fire damper	bFireDamperErrorClosingRuntime45	Error closing runtime fire damper 45	R			bool	TRUE = ok	33001	12	(0x04)
474		fire damper	bFireDamperErrorClosingRuntime46	Error closing runtime fire damper 46	R			bool	TRUE = ok	33001	13	(0x04)
475		fire damper	bFireDamperErrorClosingRuntime47	Error closing runtime fire damper 47	R			bool	TRUE = ok	33001	14	(0x04)
476		fire damper	bFireDamperErrorClosingRuntime48	Error closing runtime fire damper 48	R			bool	TRUE = ok	33001	15	(0x04)
477		fire damper	bFireDamperErrorClosingRuntime49	Error closing runtime fire damper 49	R			bool	TRUE = ok	33002	0	(0x04)
478		fire damper	bFireDamperErrorClosingRuntime50	Error closing runtime fire damper 50	R			bool	TRUE = ok	33002	1	(0x04)
479		fire damper	bFireDamperErrorClosingRuntime51	Error closing runtime fire damper 51	R			bool	TRUE = ok	33002	2	(0x04)
480		fire damper	bFireDamperErrorClosingRuntime52	Error closing runtime fire damper 52	R			bool	TRUE = ok	33002	3	(0x04)
481		fire damper	bFireDamperErrorClosingRuntime53	Error closing runtime fire damper 53	R			bool	TRUE = ok	33002	4	(0x04)
482		fire damper	bFireDamperErrorClosingRuntime54	Error closing runtime fire damper 54	R			bool	TRUE = ok	33002	5	(0x04)
483		fire damper	bFireDamperErrorClosingRuntime55	Error closing runtime fire damper 55	R			bool	TRUE = ok	33002	6	(0x04)
484		fire damper	bFireDamperErrorClosingRuntime56	Error closing runtime fire damper 56	R			bool	TRUE = ok	33002	7	(0x04)
485		fire damper	bFireDamperErrorClosingRuntime57	Error closing runtime fire damper 57	R			bool	TRUE = ok	33002	8	(0x04)
486		fire damper	bFireDamperErrorClosingRuntime58	Error closing runtime fire damper 58	R			bool	TRUE = ok	33002	9	(0x04)
487		fire damper	bFireDamperErrorClosingRuntime59	Error closing runtime fire damper 59	R			bool	TRUE = ok	33002	10	(0x04)
488		fire damper	bFireDamperErrorClosingRuntime60	Error closing runtime fire damper 60	R			bool	TRUE = ok	33002	11	(0x04)
489		fire damper	bFireDamperErrorClosingRuntime61	Error closing runtime fire damper 61	R			bool	TRUE = ok	33002	12	(0x04)
490		fire damper	bFireDamperErrorClosingRuntime62	Error closing runtime fire damper 62	R			bool	TRUE = ok	33002	13	(0x04)
491		fire damper	bFireDamperErrorOpeningRuntime1	Error Opening runtime fire damper 1	R			bool	TRUE = ok	33003	0	(0x04)
492		fire damper	bFireDamperErrorOpeningRuntime2	Error Opening runtime fire damper 2	R			bool	TRUE = ok	33003	1	(0x04)
493		fire damper	bFireDamperErrorOpeningRuntime3	Error Opening runtime fire damper 3	R			bool	TRUE = ok	33003	2	(0x04)
494		fire damper	bFireDamperErrorOpeningRuntime4	Error Opening runtime fire damper 4	R			bool	TRUE = ok	33003	3	(0x04)
495		fire damper	bFireDamperErrorOpeningRuntime5	Error Opening runtime fire damper 5	R			bool	TRUE = ok	33003	4	(0x04)
496		fire damper	bFireDamperErrorOpeningRuntime6	Error Opening runtime fire damper 6	R			bool	TRUE = ok	33003	5	(0x04)
497		fire damper	bFireDamperErrorOpeningRuntime7	Error Opening runtime fire damper 7	R			bool	TRUE = ok	33003	6	(0x04)
498		fire damper	bFireDamperErrorOpeningRuntime8	Error Opening runtime fire damper 8	R			bool	TRUE = ok	33003	7	(0x04)
499		fire damper	bFireDamperErrorOpeningRuntime9	Error Opening runtime fire damper 9	R			bool	TRUE = ok	33003	8	(0x04)
500		fire damper	bFireDamperErrorOpeningRuntime10	Error Opening runtime fire damper 10	R			bool	TRUE = ok	33003	9	(0x04)
501		fire damper	bFireDamperErrorOpeningRuntime11	Error Opening runtime fire damper 11	R			bool	TRUE = ok	33003	10	(0x04)
502		fire damper	bFireDamperErrorOpeningRuntime12	Error Opening runtime fire damper 12	R			bool	TRUE = ok	33003	11	(0x04)
503		fire damper	bFireDamperErrorOpeningRuntime13	Error Opening runtime fire damper 13	R			bool	TRUE = ok	33003	12	(0x04)
504		fire damper	bFireDamperErrorOpeningRuntime14	Error Opening runtime fire damper 14	R			bool	TRUE = ok	33003	13	(0x04)
505		fire damper	bFireDamperErrorOpeningRuntime15	Error Opening runtime fire damper 15	R			bool	TRUE = ok	33003	14	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
506		fire damper	bFireDamperErrorOpeningRuntime16	Error Opening runtime fire damper 16	R			bool	TRUE = ok	33003	15	(0x04)
507		fire damper	bFireDamperErrorOpeningRuntime17	Error Opening runtime fire damper 17	R			bool	TRUE = ok	33004	0	(0x04)
508		fire damper	bFireDamperErrorOpeningRuntime18	Error Opening runtime fire damper 18	R			bool	TRUE = ok	33004	1	(0x04)
509		fire damper	bFireDamperErrorOpeningRuntime19	Error Opening runtime fire damper 19	R			bool	TRUE = ok	33004	2	(0x04)
510		fire damper	bFireDamperErrorOpeningRuntime20	Error Opening runtime fire damper 20	R			bool	TRUE = ok	33004	3	(0x04)
511		fire damper	bFireDamperErrorOpeningRuntime21	Error Opening runtime fire damper 21	R			bool	TRUE = ok	33004	4	(0x04)
512		fire damper	bFireDamperErrorOpeningRuntime22	Error Opening runtime fire damper 22	R			bool	TRUE = ok	33004	5	(0x04)
513		fire damper	bFireDamperErrorOpeningRuntime23	Error Opening runtime fire damper 23	R			bool	TRUE = ok	33004	6	(0x04)
514		fire damper	bFireDamperErrorOpeningRuntime24	Error Opening runtime fire damper 24	R			bool	TRUE = ok	33004	7	(0x04)
515		fire damper	bFireDamperErrorOpeningRuntime25	Error Opening runtime fire damper 25	R			bool	TRUE = ok	33004	8	(0x04)
516		fire damper	bFireDamperErrorOpeningRuntime26	Error Opening runtime fire damper 26	R			bool	TRUE = ok	33004	9	(0x04)
517		fire damper	bFireDamperErrorOpeningRuntime27	Error Opening runtime fire damper 27	R			bool	TRUE = ok	33004	10	(0x04)
518		fire damper	bFireDamperErrorOpeningRuntime28	Error Opening runtime fire damper 28	R			bool	TRUE = ok	33004	11	(0x04)
519		fire damper	bFireDamperErrorOpeningRuntime29	Error Opening runtime fire damper 29	R			bool	TRUE = ok	33004	12	(0x04)
520		fire damper	bFireDamperErrorOpeningRuntime30	Error Opening runtime fire damper 30	R			bool	TRUE = ok	33004	13	(0x04)
521		fire damper	bFireDamperErrorOpeningRuntime31	Error Opening runtime fire damper 31	R			bool	TRUE = ok	33004	14	(0x04)
522		fire damper	bFireDamperErrorOpeningRuntime32	Error Opening runtime fire damper 32	R			bool	TRUE = ok	33004	15	(0x04)
523		fire damper	bFireDamperErrorOpeningRuntime33	Error Opening runtime fire damper 33	R			bool	TRUE = ok	33005	0	(0x04)
524		fire damper	bFireDamperErrorOpeningRuntime34	Error Opening runtime fire damper 34	R			bool	TRUE = ok	33005	1	(0x04)
525		fire damper	bFireDamperErrorOpeningRuntime35	Error Opening runtime fire damper 35	R			bool	TRUE = ok	33005	2	(0x04)
526		fire damper	bFireDamperErrorOpeningRuntime36	Error Opening runtime fire damper 36	R			bool	TRUE = ok	33005	3	(0x04)
527		fire damper	bFireDamperErrorOpeningRuntime37	Error Opening runtime fire damper 37	R			bool	TRUE = ok	33005	4	(0x04)
528		fire damper	bFireDamperErrorOpeningRuntime38	Error Opening runtime fire damper 38	R			bool	TRUE = ok	33005	5	(0x04)
529		fire damper	bFireDamperErrorOpeningRuntime39	Error Opening runtime fire damper 39	R			bool	TRUE = ok	33005	6	(0x04)
530		fire damper	bFireDamperErrorOpeningRuntime40	Error Opening runtime fire damper 40	R			bool	TRUE = ok	33005	7	(0x04)
531		fire damper	bFireDamperErrorOpeningRuntime41	Error Opening runtime fire damper 41	R			bool	TRUE = ok	33005	8	(0x04)
532		fire damper	bFireDamperErrorOpeningRuntime42	Error Opening runtime fire damper 42	R			bool	TRUE = ok	33005	9	(0x04)
533		fire damper	bFireDamperErrorOpeningRuntime43	Error Opening runtime fire damper 43	R			bool	TRUE = ok	33005	10	(0x04)
534		fire damper	bFireDamperErrorOpeningRuntime44	Error Opening runtime fire damper 44	R			bool	TRUE = ok	33005	11	(0x04)
535		fire damper	bFireDamperErrorOpeningRuntime45	Error Opening runtime fire damper 45	R			bool	TRUE = ok	33005	12	(0x04)
536		fire damper	bFireDamperErrorOpeningRuntime46	Error Opening runtime fire damper 46	R			bool	TRUE = ok	33005	13	(0x04)
537		fire damper	bFireDamperErrorOpeningRuntime47	Error Opening runtime fire damper 47	R			bool	TRUE = ok	33005	14	(0x04)
538		fire damper	bFireDamperErrorOpeningRuntime48	Error Opening runtime fire damper 48	R			bool	TRUE = ok	33005	15	(0x04)
539		fire damper	bFireDamperErrorOpeningRuntime49	Error Opening runtime fire damper 49	R			bool	TRUE = ok	33006	0	(0x04)
540		fire damper	bFireDamperErrorOpeningRuntime50	Error Opening runtime fire damper 50	R			bool	TRUE = ok	33006	1	(0x04)
541		fire damper	bFireDamperErrorOpeningRuntime51	Error Opening runtime fire damper 51	R			bool	TRUE = ok	33006	2	(0x04)
542		fire damper	bFireDamperErrorOpeningRuntime52	Error Opening runtime fire damper 52	R			bool	TRUE = ok	33006	3	(0x04)
543		fire damper	bFireDamperErrorOpeningRuntime53	Error Opening runtime fire damper 53	R			bool	TRUE = ok	33006	4	(0x04)
544		fire damper	bFireDamperErrorOpeningRuntime54	Error Opening runtime fire damper 54	R			bool	TRUE = ok	33006	5	(0x04)
545		fire damper	bFireDamperErrorOpeningRuntime55	Error Opening runtime fire damper 55	R			bool	TRUE = ok	33006	6	(0x04)
546		fire damper	bFireDamperErrorOpeningRuntime56	Error Opening runtime fire damper 56	R			bool	TRUE = ok	33006	7	(0x04)
547		fire damper	bFireDamperErrorOpeningRuntime57	Error Opening runtime fire damper 57	R			bool	TRUE = ok	33006	8	(0x04)
548		fire damper	bFireDamperErrorOpeningRuntime58	Error Opening runtime fire damper 58	R			bool	TRUE = ok	33006	9	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
549		fire damper	bFireDamperErrorOpeningRuntime59	Error Opening runtime fire damper 59	R			bool	TRUE = ok	33006	10	(0x04)
550		fire damper	bFireDamperErrorOpeningRuntime60	Error Opening runtime fire damper 60	R			bool	TRUE = ok	33006	11	(0x04)
551		fire damper	bFireDamperErrorOpeningRuntime61	Error Opening runtime fire damper 61	R			bool	TRUE = ok	33006	12	(0x04)
552		fire damper	bFireDamperErrorOpeningRuntime62	Error Opening runtime fire damper 62	R			bool	TRUE = ok	33006	13	(0x04)
553		fire damper	bFireDamperErrorPositionIndicator1	Error end switch fire damper 1	R			bool	TRUE = ok	33007	0	(0x04)
554		fire damper	bFireDamperErrorPositionIndicator2	Error end switch fire damper 2	R			bool	TRUE = ok	33007	1	(0x04)
555		fire damper	bFireDamperErrorPositionIndicator3	Error end switch fire damper 3	R			bool	TRUE = ok	33007	2	(0x04)
556		fire damper	bFireDamperErrorPositionIndicator4	Error end switch fire damper 4	R			bool	TRUE = ok	33007	3	(0x04)
557		fire damper	bFireDamperErrorPositionIndicator5	Error end switch fire damper 5	R			bool	TRUE = ok	33007	4	(0x04)
558		fire damper	bFireDamperErrorPositionIndicator6	Error end switch fire damper 6	R			bool	TRUE = ok	33007	5	(0x04)
559		fire damper	bFireDamperErrorPositionIndicator7	Error end switch fire damper 7	R			bool	TRUE = ok	33007	6	(0x04)
560		fire damper	bFireDamperErrorPositionIndicator8	Error end switch fire damper 8	R			bool	TRUE = ok	33007	7	(0x04)
561		fire damper	bFireDamperErrorPositionIndicator9	Error end switch fire damper 9	R			bool	TRUE = ok	33007	8	(0x04)
562		fire damper	bFireDamperErrorPositionIndicator10	Error end switch fire damper 10	R			bool	TRUE = ok	33007	9	(0x04)
563		fire damper	bFireDamperErrorPositionIndicator11	Error end switch fire damper 11	R			bool	TRUE = ok	33007	10	(0x04)
564		fire damper	bFireDamperErrorPositionIndicator12	Error end switch fire damper 12	R			bool	TRUE = ok	33007	11	(0x04)
565		fire damper	bFireDamperErrorPositionIndicator13	Error end switch fire damper 13	R			bool	TRUE = ok	33007	12	(0x04)
566		fire damper	bFireDamperErrorPositionIndicator14	Error end switch fire damper 14	R			bool	TRUE = ok	33007	13	(0x04)
567		fire damper	bFireDamperErrorPositionIndicator15	Error end switch fire damper 15	R			bool	TRUE = ok	33007	14	(0x04)
568		fire damper	bFireDamperErrorPositionIndicator16	Error end switch fire damper 16	R			bool	TRUE = ok	33007	15	(0x04)
569		fire damper	bFireDamperErrorPositionIndicator17	Error end switch fire damper 17	R			bool	TRUE = ok	33008	0	(0x04)
570		fire damper	bFireDamperErrorPositionIndicator18	Error end switch fire damper 18	R			bool	TRUE = ok	33008	1	(0x04)
571		fire damper	bFireDamperErrorPositionIndicator19	Error end switch fire damper 19	R			bool	TRUE = ok	33008	2	(0x04)
572		fire damper	bFireDamperErrorPositionIndicator20	Error end switch fire damper 20	R			bool	TRUE = ok	33008	3	(0x04)
573		fire damper	bFireDamperErrorPositionIndicator21	Error end switch fire damper 21	R			bool	TRUE = ok	33008	4	(0x04)
574		fire damper	bFireDamperErrorPositionIndicator22	Error end switch fire damper 22	R			bool	TRUE = ok	33008	5	(0x04)
575		fire damper	bFireDamperErrorPositionIndicator23	Error end switch fire damper 23	R			bool	TRUE = ok	33008	6	(0x04)
576		fire damper	bFireDamperErrorPositionIndicator24	Error end switch fire damper 24	R			bool	TRUE = ok	33008	7	(0x04)
577		fire damper	bFireDamperErrorPositionIndicator25	Error end switch fire damper 25	R			bool	TRUE = ok	33008	8	(0x04)
578		fire damper	bFireDamperErrorPositionIndicator26	Error end switch fire damper 26	R			bool	TRUE = ok	33008	9	(0x04)
579		fire damper	bFireDamperErrorPositionIndicator27	Error end switch fire damper 27	R			bool	TRUE = ok	33008	10	(0x04)
580		fire damper	bFireDamperErrorPositionIndicator28	Error end switch fire damper 28	R			bool	TRUE = ok	33008	11	(0x04)
581		fire damper	bFireDamperErrorPositionIndicator29	Error end switch fire damper 29	R			bool	TRUE = ok	33008	12	(0x04)
582		fire damper	bFireDamperErrorPositionIndicator30	Error end switch fire damper 30	R			bool	TRUE = ok	33008	13	(0x04)
583		fire damper	bFireDamperErrorPositionIndicator31	Error end switch fire damper 31	R			bool	TRUE = ok	33008	14	(0x04)
584		fire damper	bFireDamperErrorPositionIndicator32	Error end switch fire damper 32	R			bool	TRUE = ok	33008	15	(0x04)
585		fire damper	bFireDamperErrorPositionIndicator33	Error end switch fire damper 33	R			bool	TRUE = ok	33009	0	(0x04)
586		fire damper	bFireDamperErrorPositionIndicator34	Error end switch fire damper 34	R			bool	TRUE = ok	33009	1	(0x04)
587		fire damper	bFireDamperErrorPositionIndicator35	Error end switch fire damper 35	R			bool	TRUE = ok	33009	2	(0x04)
588		fire damper	bFireDamperErrorPositionIndicator36	Error end switch fire damper 36	R			bool	TRUE = ok	33009	3	(0x04)
589		fire damper	bFireDamperErrorPositionIndicator37	Error end switch fire damper 37	R			bool	TRUE = ok	33009	4	(0x04)
590		fire damper	bFireDamperErrorPositionIndicator38	Error end switch fire damper 38	R			bool	TRUE = ok	33009	5	(0x04)
591		fire damper	bFireDamperErrorPositionIndicator39	Error end switch fire damper 39	R			bool	TRUE = ok	33009	6	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
592		fire damper	bFireDamperErrorPositionIndicator40	Error end switch fire damper 40	R			bool	TRUE = ok	33009	7	(0x04)
593		fire damper	bFireDamperErrorPositionIndicator41	Error end switch fire damper 41	R			bool	TRUE = ok	33009	8	(0x04)
594		fire damper	bFireDamperErrorPositionIndicator42	Error end switch fire damper 42	R			bool	TRUE = ok	33009	9	(0x04)
595		fire damper	bFireDamperErrorPositionIndicator43	Error end switch fire damper 43	R			bool	TRUE = ok	33009	10	(0x04)
596		fire damper	bFireDamperErrorPositionIndicator44	Error end switch fire damper 44	R			bool	TRUE = ok	33009	11	(0x04)
597		fire damper	bFireDamperErrorPositionIndicator45	Error end switch fire damper 45	R			bool	TRUE = ok	33009	12	(0x04)
598		fire damper	bFireDamperErrorPositionIndicator46	Error end switch fire damper 46	R			bool	TRUE = ok	33009	13	(0x04)
599		fire damper	bFireDamperErrorPositionIndicator47	Error end switch fire damper 47	R			bool	TRUE = ok	33009	14	(0x04)
600		fire damper	bFireDamperErrorPositionIndicator48	Error end switch fire damper 48	R			bool	TRUE = ok	33009	15	(0x04)
601		fire damper	bFireDamperErrorPositionIndicator49	Error end switch fire damper 49	R			bool	TRUE = ok	33010	0	(0x04)
602		fire damper	bFireDamperErrorPositionIndicator50	Error end switch fire damper 50	R			bool	TRUE = ok	33010	1	(0x04)
603		fire damper	bFireDamperErrorPositionIndicator51	Error end switch fire damper 51	R			bool	TRUE = ok	33010	2	(0x04)
604		fire damper	bFireDamperErrorPositionIndicator52	Error end switch fire damper 52	R			bool	TRUE = ok	33010	3	(0x04)
605		fire damper	bFireDamperErrorPositionIndicator53	Error end switch fire damper 53	R			bool	TRUE = ok	33010	4	(0x04)
606		fire damper	bFireDamperErrorPositionIndicator54	Error end switch fire damper 54	R			bool	TRUE = ok	33010	5	(0x04)
607		fire damper	bFireDamperErrorPositionIndicator55	Error end switch fire damper 55	R			bool	TRUE = ok	33010	6	(0x04)
608		fire damper	bFireDamperErrorPositionIndicator56	Error end switch fire damper 56	R			bool	TRUE = ok	33010	7	(0x04)
609		fire damper	bFireDamperErrorPositionIndicator57	Error end switch fire damper 57	R			bool	TRUE = ok	33010	8	(0x04)
610		fire damper	bFireDamperErrorPositionIndicator58	Error end switch fire damper 58	R			bool	TRUE = ok	33010	9	(0x04)
611		fire damper	bFireDamperErrorPositionIndicator59	Error end switch fire damper 59	R			bool	TRUE = ok	33010	10	(0x04)
612		fire damper	bFireDamperErrorPositionIndicator60	Error end switch fire damper 60	R			bool	TRUE = ok	33010	11	(0x04)
613		fire damper	bFireDamperErrorPositionIndicator61	Error end switch fire damper 61	R			bool	TRUE = ok	33010	12	(0x04)
614		fire damper	bFireDamperErrorPositionIndicator62	Error end switch fire damper 62	R			bool	TRUE = ok	33010	13	(0x04)
615		fire damper	bFireDamper1	Error triggered fire damper 1	R			bool	TRUE = ok	33011	0	(0x04)
616		fire damper	bFireDamper2	Error triggered fire damper 2	R			bool	TRUE = ok	33011	1	(0x04)
617		fire damper	bFireDamper3	Error triggered fire damper 3	R			bool	TRUE = ok	33011	2	(0x04)
618		fire damper	bFireDamper4	Error triggered fire damper 4	R			bool	TRUE = ok	33011	3	(0x04)
619		fire damper	bFireDamper5	Error triggered fire damper 5	R			bool	TRUE = ok	33011	4	(0x04)
620		fire damper	bFireDamper6	Error triggered fire damper 6	R			bool	TRUE = ok	33011	5	(0x04)
621		fire damper	bFireDamper7	Error triggered fire damper 7	R			bool	TRUE = ok	33011	6	(0x04)
622		fire damper	bFireDamper8	Error triggered fire damper 8	R			bool	TRUE = ok	33011	7	(0x04)
623		fire damper	bFireDamper9	Error triggered fire damper 9	R			bool	TRUE = ok	33011	8	(0x04)
624		fire damper	bFireDamper10	Error triggered fire damper 10	R			bool	TRUE = ok	33011	9	(0x04)
625		fire damper	bFireDamper11	Error triggered fire damper 11	R			bool	TRUE = ok	33011	10	(0x04)
626		fire damper	bFireDamper12	Error triggered fire damper 12	R			bool	TRUE = ok	33011	11	(0x04)
627		fire damper	bFireDamper13	Error triggered fire damper 13	R			bool	TRUE = ok	33011	12	(0x04)
628		fire damper	bFireDamper14	Error triggered fire damper 14	R			bool	TRUE = ok	33011	13	(0x04)
629		fire damper	bFireDamper15	Error triggered fire damper 15	R			bool	TRUE = ok	33011	14	(0x04)
630		fire damper	bFireDamper16	Error triggered fire damper 16	R			bool	TRUE = ok	33011	15	(0x04)
631		fire damper	bFireDamper17	Error triggered fire damper 17	R			bool	TRUE = ok	33012	0	(0x04)
632		fire damper	bFireDamper18	Error triggered fire damper 18	R			bool	TRUE = ok	33012	1	(0x04)
633		fire damper	bFireDamper19	Error triggered fire damper 19	R			bool	TRUE = ok	33012	2	(0x04)
634		fire damper	bFireDamper20	Error triggered fire damper 20	R			bool	TRUE = ok	33012	3	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
635		fire damper	bFireDamper21	Error triggered fire damper 21	R			bool	TRUE = ok	33012	4	(0x04)
636		fire damper	bFireDamper22	Error triggered fire damper 22	R			bool	TRUE = ok	33012	5	(0x04)
637		fire damper	bFireDamper23	Error triggered fire damper 23	R			bool	TRUE = ok	33012	6	(0x04)
638		fire damper	bFireDamper24	Error triggered fire damper 24	R			bool	TRUE = ok	33012	7	(0x04)
639		fire damper	bFireDamper25	Error triggered fire damper 25	R			bool	TRUE = ok	33012	8	(0x04)
640		fire damper	bFireDamper26	Error triggered fire damper 26	R			bool	TRUE = ok	33012	9	(0x04)
641		fire damper	bFireDamper27	Error triggered fire damper 27	R			bool	TRUE = ok	33012	10	(0x04)
642		fire damper	bFireDamper28	Error triggered fire damper 28	R			bool	TRUE = ok	33012	11	(0x04)
643		fire damper	bFireDamper29	Error triggered fire damper 29	R			bool	TRUE = ok	33012	12	(0x04)
644		fire damper	bFireDamper30	Error triggered fire damper 30	R			bool	TRUE = ok	33012	13	(0x04)
645		fire damper	bFireDamper31	Error triggered fire damper 31	R			bool	TRUE = ok	33012	14	(0x04)
646		fire damper	bFireDamper32	Error triggered fire damper 32	R			bool	TRUE = ok	33012	15	(0x04)
647		fire damper	bFireDamper33	Error triggered fire damper 33	R			bool	TRUE = ok	33013	0	(0x04)
648		fire damper	bFireDamper34	Error triggered fire damper 34	R			bool	TRUE = ok	33013	1	(0x04)
649		fire damper	bFireDamper35	Error triggered fire damper 35	R			bool	TRUE = ok	33013	2	(0x04)
650		fire damper	bFireDamper36	Error triggered fire damper 36	R			bool	TRUE = ok	33013	3	(0x04)
651		fire damper	bFireDamper37	Error triggered fire damper 37	R			bool	TRUE = ok	33013	4	(0x04)
652		fire damper	bFireDamper38	Error triggered fire damper 38	R			bool	TRUE = ok	33013	5	(0x04)
653		fire damper	bFireDamper39	Error triggered fire damper 39	R			bool	TRUE = ok	33013	6	(0x04)
654		fire damper	bFireDamper40	Error triggered fire damper 40	R			bool	TRUE = ok	33013	7	(0x04)
655		fire damper	bFireDamper41	Error triggered fire damper 41	R			bool	TRUE = ok	33013	8	(0x04)
656		fire damper	bFireDamper42	Error triggered fire damper 42	R			bool	TRUE = ok	33013	9	(0x04)
657		fire damper	bFireDamper43	Error triggered fire damper 43	R			bool	TRUE = ok	33013	10	(0x04)
658		fire damper	bFireDamper44	Error triggered fire damper 44	R			bool	TRUE = ok	33013	11	(0x04)
659		fire damper	bFireDamper45	Error triggered fire damper 45	R			bool	TRUE = ok	33013	12	(0x04)
660		fire damper	bFireDamper46	Error triggered fire damper 46	R			bool	TRUE = ok	33013	13	(0x04)
661		fire damper	bFireDamper47	Error triggered fire damper 47	R			bool	TRUE = ok	33013	14	(0x04)
662		fire damper	bFireDamper48	Error triggered fire damper 48	R			bool	TRUE = ok	33013	15	(0x04)
663		fire damper	bFireDamper49	Error triggered fire damper 49	R			bool	TRUE = ok	33014	0	(0x04)
664		fire damper	bFireDamper50	Error triggered fire damper 50	R			bool	TRUE = ok	33014	1	(0x04)
665		fire damper	bFireDamper51	Error triggered fire damper 51	R			bool	TRUE = ok	33014	2	(0x04)
666		fire damper	bFireDamper52	Error triggered fire damper 52	R			bool	TRUE = ok	33014	3	(0x04)
667		fire damper	bFireDamper53	Error triggered fire damper 53	R			bool	TRUE = ok	33014	4	(0x04)
668		fire damper	bFireDamper54	Error triggered fire damper 54	R			bool	TRUE = ok	33014	5	(0x04)
669		fire damper	bFireDamper55	Error triggered fire damper 55	R			bool	TRUE = ok	33014	6	(0x04)
670		fire damper	bFireDamper56	Error triggered fire damper 56	R			bool	TRUE = ok	33014	7	(0x04)
671		fire damper	bFireDamper57	Error triggered fire damper 57	R			bool	TRUE = ok	33014	8	(0x04)
672		fire damper	bFireDamper58	Error triggered fire damper 58	R			bool	TRUE = ok	33014	9	(0x04)
673		fire damper	bFireDamper59	Error triggered fire damper 59	R			bool	TRUE = ok	33014	10	(0x04)
674		fire damper	bFireDamper60	Error triggered fire damper 60	R			bool	TRUE = ok	33014	11	(0x04)
675		fire damper	bFireDamper61	Error triggered fire damper 61	R			bool	TRUE = ok	33014	12	(0x04)
676		fire damper	bFireDamper62	Error triggered fire damper 62	R			bool	TRUE = ok	33014	13	(0x04)
677		supply air fan 3 to 16	bFanCtrlOperationSUP3	controlled value operation signal of the supply air fan 3	R			bool	TRUE = on	33015	0	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
678		supply air fan 3 to 16	bFanCtrlOperationSUP4	controlled value operation signal of the supply air fan 4	R			bool	TRUE = on	33015	1	(0x04)
679		supply air fan 3 to 16	bFanCtrlOperationSUP5	controlled value operation signal of the supply air fan 5	R			bool	TRUE = on	33015	2	(0x04)
680		supply air fan 3 to 16	bFanCtrlOperationSUP6	controlled value operation signal of the supply air fan 6	R			bool	TRUE = on	33015	3	(0x04)
681		supply air fan 3 to 16	bFanCtrlOperationSUP7	controlled value operation signal of the supply air fan 7	R			bool	TRUE = on	33015	4	(0x04)
682		supply air fan 3 to 16	bFanCtrlOperationSUP8	controlled value operation signal of the supply air fan 8	R			bool	TRUE = on	33015	5	(0x04)
683		supply air fan 3 to 16	bFanCtrlOperationSUP9	controlled value operation signal of the supply air fan 9	R			bool	TRUE = on	33015	6	(0x04)
684		supply air fan 3 to 16	bFanCtrlOperationSUP10	controlled value operation signal of the supply air fan 10	R			bool	TRUE = on	33015	7	(0x04)
685		supply air fan 3 to 16	bFanCtrlOperationSUP11	controlled value operation signal of the supply air fan 11	R			bool	TRUE = on	33015	8	(0x04)
686		supply air fan 3 to 16	bFanCtrlOperationSUP12	controlled value operation signal of the supply air fan 12	R			bool	TRUE = on	33015	9	(0x04)
687		supply air fan 3 to 16	bFanCtrlOperationSUP13	controlled value operation signal of the supply air fan 13	R			bool	TRUE = on	33015	10	(0x04)
688		supply air fan 3 to 16	bFanCtrlOperationSUP14	controlled value operation signal of the supply air fan 14	R			bool	TRUE = on	33015	11	(0x04)
689		supply air fan 3 to 16	bFanCtrlOperationSUP15	controlled value operation signal of the supply air fan 15	R			bool	TRUE = on	33015	12	(0x04)
690		supply air fan 3 to 16	bFanCtrlOperationSUP16	controlled value operation signal of the supply air fan 16	R			bool	TRUE = on	33015	13	(0x04)
691		supply air fan 3 to 16	bFanStateErrorSUP3	internal error supply air fan 3	R			bool	TRUE = ok	33016	0	(0x04)
692		supply air fan 3 to 16	bFanStateErrorSUP4	internal error supply air fan 4	R			bool	TRUE = ok	33016	1	(0x04)
693		supply air fan 3 to 16	bFanStateErrorSUP5	internal error supply air fan 5	R			bool	TRUE = ok	33016	2	(0x04)
694		supply air fan 3 to 16	bFanStateErrorSUP6	internal error supply air fan 6	R			bool	TRUE = ok	33016	3	(0x04)
695		supply air fan 3 to 16	bFanStateErrorSUP7	internal error supply air fan 7	R			bool	TRUE = ok	33016	4	(0x04)
696		supply air fan 3 to 16	bFanStateErrorSUP8	internal error supply air fan 8	R			bool	TRUE = ok	33016	5	(0x04)
697		supply air fan 3 to 16	bFanStateErrorSUP9	internal error supply air fan 9	R			bool	TRUE = ok	33016	6	(0x04)
698		supply air fan 3 to 16	bFanStateErrorSUP10	internal error supply air fan 10	R			bool	TRUE = ok	33016	7	(0x04)
699		supply air fan 3 to 16	bFanStateErrorSUP11	internal error supply air fan 11	R			bool	TRUE = ok	33016	8	(0x04)
700		supply air fan 3 to 16	bFanStateErrorSUP12	internal error supply air fan 12	R			bool	TRUE = ok	33016	9	(0x04)
701		supply air fan 3 to 16	bFanStateErrorSUP13	internal error supply air fan 13	R			bool	TRUE = ok	33016	10	(0x04)
702		supply air fan 3 to 16	bFanStateErrorSUP14	internal error supply air fan 14	R			bool	TRUE = ok	33016	11	(0x04)
703		supply air fan 3 to 16	bFanStateErrorSUP15	internal error supply air fan 15	R			bool	TRUE = ok	33016	12	(0x04)
704		supply air fan 3 to 16	bFanStateErrorSUP16	internal error supply air fan 16	R			bool	TRUE = ok	33016	13	(0x04)
705		supply air fan 3 to 16	bFanStateErrModbusFuSUP3	modbus comm. error with the supply air fan 3	R			bool	TRUE = ok	33017	0	(0x04)
706		supply air fan 3 to 16	bFanStateErrModbusFuSUP4	modbus comm. error with the supply air fan 4	R			bool	TRUE = ok	33017	1	(0x04)
707		supply air fan 3 to 16	bFanStateErrModbusFuSUP5	modbus comm. error with the supply air fan 5	R			bool	TRUE = ok	33017	2	(0x04)
708		supply air fan 3 to 16	bFanStateErrModbusFuSUP6	modbus comm. error with the supply air fan 6	R			bool	TRUE = ok	33017	3	(0x04)
709		supply air fan 3 to 16	bFanStateErrModbusFuSUP7	modbus comm. error with the supply air fan 7	R			bool	TRUE = ok	33017	4	(0x04)
710		supply air fan 3 to 16	bFanStateErrModbusFuSUP8	modbus comm. error with the supply air fan 8	R			bool	TRUE = ok	33017	5	(0x04)
711		supply air fan 3 to 16	bFanStateErrModbusFuSUP9	modbus comm. error with the supply air fan 9	R			bool	TRUE = ok	33017	6	(0x04)
712		supply air fan 3 to 16	bFanStateErrModbusFuSUP10	modbus comm. error with the supply air fan 10	R			bool	TRUE = ok	33017	7	(0x04)
713		supply air fan 3 to 16	bFanStateErrModbusFuSUP11	modbus comm. error with the supply air fan 11	R			bool	TRUE = ok	33017	8	(0x04)
714		supply air fan 3 to 16	bFanStateErrModbusFuSUP12	modbus comm. error with the supply air fan 12	R			bool	TRUE = ok	33017	9	(0x04)
715		supply air fan 3 to 16	bFanStateErrModbusFuSUP13	modbus comm. error with the supply air fan 13	R			bool	TRUE = ok	33017	10	(0x04)
716		supply air fan 3 to 16	bFanStateErrModbusFuSUP14	modbus comm. error with the supply air fan 14	R			bool	TRUE = ok	33017	11	(0x04)
717		supply air fan 3 to 16	bFanStateErrModbusFuSUP15	modbus comm. error with the supply air fan 15	R			bool	TRUE = ok	33017	12	(0x04)
718		supply air fan 3 to 16	bFanStateErrModbusFuSUP16	modbus comm. error with the supply air fan 16	R			bool	TRUE = ok	33017	13	(0x04)
719		supply air fan 3 to 16	bFanStateRepairSwitchSUP3	repair switch of the supply air fan is active 3	R			bool	TRUE = ok	33018	0	(0x04)
720		supply air fan 3 to 16	bFanStateRepairSwitchSUP4	repair switch of the supply air fan is active 4	R			bool	TRUE = ok	33018	1	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
721		supply air fan 3 to 16	bFanStateRepairSwitchSUP5	repair switch of the supply air fan is active 5	R			bool	TRUE = ok	33018	2	(0x04)
722		supply air fan 3 to 16	bFanStateRepairSwitchSUP6	repair switch of the supply air fan is active 6	R			bool	TRUE = ok	33018	3	(0x04)
723		supply air fan 3 to 16	bFanStateRepairSwitchSUP7	repair switch of the supply air fan is active 7	R			bool	TRUE = ok	33018	4	(0x04)
724		supply air fan 3 to 16	bFanStateRepairSwitchSUP8	repair switch of the supply air fan is active 8	R			bool	TRUE = ok	33018	5	(0x04)
725		supply air fan 3 to 16	bFanStateRepairSwitchSUP9	repair switch of the supply air fan is active 9	R			bool	TRUE = ok	33018	6	(0x04)
726		supply air fan 3 to 16	bFanStateRepairSwitchSUP10	repair switch of the supply air fan is active 10	R			bool	TRUE = ok	33018	7	(0x04)
727		supply air fan 3 to 16	bFanStateRepairSwitchSUP11	repair switch of the supply air fan is active 11	R			bool	TRUE = ok	33018	8	(0x04)
728		supply air fan 3 to 16	bFanStateRepairSwitchSUP12	repair switch of the supply air fan is active 12	R			bool	TRUE = ok	33018	9	(0x04)
729		supply air fan 3 to 16	bFanStateRepairSwitchSUP13	repair switch of the supply air fan is active 13	R			bool	TRUE = ok	33018	10	(0x04)
730		supply air fan 3 to 16	bFanStateRepairSwitchSUP14	repair switch of the supply air fan is active 14	R			bool	TRUE = ok	33018	11	(0x04)
731		supply air fan 3 to 16	bFanStateRepairSwitchSUP15	repair switch of the supply air fan is active 15	R			bool	TRUE = ok	33018	12	(0x04)
732		supply air fan 3 to 16	bFanStateRepairSwitchSUP16	repair switch of the supply air fan is active 16	R			bool	TRUE = ok	33018	13	(0x04)
733		extract air fan 3 to 16	bFanCtrlOperationETA3	controlled value operation signal of the extract air fan 3	R			bool	TRUE = on	33019	0	(0x04)
734		extract air fan 3 to 16	bFanCtrlOperationETA4	controlled value operation signal of the extract air fan 4	R			bool	TRUE = on	33019	1	(0x04)
735		extract air fan 3 to 16	bFanCtrlOperationETA5	controlled value operation signal of the extract air fan 5	R			bool	TRUE = on	33019	2	(0x04)
736		extract air fan 3 to 16	bFanCtrlOperationETA6	controlled value operation signal of the extract air fan 6	R			bool	TRUE = on	33019	3	(0x04)
737		extract air fan 3 to 16	bFanCtrlOperationETA7	controlled value operation signal of the extract air fan 7	R			bool	TRUE = on	33019	4	(0x04)
738		extract air fan 3 to 16	bFanCtrlOperationETA8	controlled value operation signal of the extract air fan 8	R			bool	TRUE = on	33019	5	(0x04)
739		extract air fan 3 to 16	bFanCtrlOperationETA9	controlled value operation signal of the extract air fan 9	R			bool	TRUE = on	33019	6	(0x04)
740		extract air fan 3 to 16	bFanCtrlOperationETA10	controlled value operation signal of the extract air fan 10	R			bool	TRUE = on	33019	7	(0x04)
741		extract air fan 3 to 16	bFanCtrlOperationETA11	controlled value operation signal of the extract air fan 11	R			bool	TRUE = on	33019	8	(0x04)
742		extract air fan 3 to 16	bFanCtrlOperationETA12	controlled value operation signal of the extract air fan 12	R			bool	TRUE = on	33019	9	(0x04)
743		extract air fan 3 to 16	bFanCtrlOperationETA13	controlled value operation signal of the extract air fan 13	R			bool	TRUE = on	33019	10	(0x04)
744		extract air fan 3 to 16	bFanCtrlOperationETA14	controlled value operation signal of the extract air fan 14	R			bool	TRUE = on	33019	11	(0x04)
745		extract air fan 3 to 16	bFanCtrlOperationETA15	controlled value operation signal of the extract air fan 15	R			bool	TRUE = on	33019	12	(0x04)
746		extract air fan 3 to 16	bFanCtrlOperationETA16	controlled value operation signal of the extract air fan 16	R			bool	TRUE = on	33019	13	(0x04)
747		extract air fan 3 to 16	bFanStateErrorETA3	internal error extract air fan 3	R			bool	TRUE = ok	33020	0	(0x04)
748		extract air fan 3 to 16	bFanStateErrorETA4	internal error extract air fan 4	R			bool	TRUE = ok	33020	1	(0x04)
749		extract air fan 3 to 16	bFanStateErrorETA5	internal error extract air fan 5	R			bool	TRUE = ok	33020	2	(0x04)
750		extract air fan 3 to 16	bFanStateErrorETA6	internal error extract air fan 6	R			bool	TRUE = ok	33020	3	(0x04)
751		extract air fan 3 to 16	bFanStateErrorETA7	internal error extract air fan 7	R			bool	TRUE = ok	33020	4	(0x04)
752		extract air fan 3 to 16	bFanStateErrorETA8	internal error extract air fan 8	R			bool	TRUE = ok	33020	5	(0x04)
753		extract air fan 3 to 16	bFanStateErrorETA9	internal error extract air fan 9	R			bool	TRUE = ok	33020	6	(0x04)
754		extract air fan 3 to 16	bFanStateErrorETA10	internal error extract air fan 10	R			bool	TRUE = ok	33020	7	(0x04)
755		extract air fan 3 to 16	bFanStateErrorETA11	internal error extract air fan 11	R			bool	TRUE = ok	33020	8	(0x04)
756		extract air fan 3 to 16	bFanStateErrorETA12	internal error extract air fan 12	R			bool	TRUE = ok	33020	9	(0x04)
757		extract air fan 3 to 16	bFanStateErrorETA13	internal error extract air fan 13	R			bool	TRUE = ok	33020	10	(0x04)
758		extract air fan 3 to 16	bFanStateErrorETA14	internal error extract air fan 14	R			bool	TRUE = ok	33020	11	(0x04)
759		extract air fan 3 to 16	bFanStateErrorETA15	internal error extract air fan 15	R			bool	TRUE = ok	33020	12	(0x04)
760		extract air fan 3 to 16	bFanStateErrorETA16	internal error extract air fan 16	R			bool	TRUE = ok	33020	13	(0x04)
761		extract air fan 3 to 16	bFanStateErrModbusFuETA3	modbus comm. error with the extract air fan 3	R			bool	TRUE = ok	33021	0	(0x04)
762		extract air fan 3 to 16	bFanStateErrModbusFuETA4	modbus comm. error with the extract air fan 4	R			bool	TRUE = ok	33021	1	(0x04)
763		extract air fan 3 to 16	bFanStateErrModbusFuETA5	modbus comm. error with the extract air fan 5	R			bool	TRUE = ok	33021	2	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
764		extract air fan 3 to 16	bFanStateErrModbusFuETA6	modbus comm. error with the extract air fan 6	R			bool	TRUE = ok	33021	3	(0x04)
765		extract air fan 3 to 16	bFanStateErrModbusFuETA7	modbus comm. error with the extract air fan 7	R			bool	TRUE = ok	33021	4	(0x04)
766		extract air fan 3 to 16	bFanStateErrModbusFuETA8	modbus comm. error with the extract air fan 8	R			bool	TRUE = ok	33021	5	(0x04)
767		extract air fan 3 to 16	bFanStateErrModbusFuETA9	modbus comm. error with the extract air fan 9	R			bool	TRUE = ok	33021	6	(0x04)
768		extract air fan 3 to 16	bFanStateErrModbusFuETA10	modbus comm. error with the extract air fan 10	R			bool	TRUE = ok	33021	7	(0x04)
769		extract air fan 3 to 16	bFanStateErrModbusFuETA11	modbus comm. error with the extract air fan 11	R			bool	TRUE = ok	33021	8	(0x04)
770		extract air fan 3 to 16	bFanStateErrModbusFuETA12	modbus comm. error with the extract air fan 12	R			bool	TRUE = ok	33021	9	(0x04)
771		extract air fan 3 to 16	bFanStateErrModbusFuETA13	modbus comm. error with the extract air fan 13	R			bool	TRUE = ok	33021	10	(0x04)
772		extract air fan 3 to 16	bFanStateErrModbusFuETA14	modbus comm. error with the extract air fan 14	R			bool	TRUE = ok	33021	11	(0x04)
773		extract air fan 3 to 16	bFanStateErrModbusFuETA15	modbus comm. error with the extract air fan 15	R			bool	TRUE = ok	33021	12	(0x04)
774		extract air fan 3 to 16	bFanStateErrModbusFuETA16	modbus comm. error with the extract air fan 16	R			bool	TRUE = ok	33021	13	(0x04)
775		extract air fan 3 to 16	bFanStateRepairSwitchETA3	repair switch of the extract air fan is active 3	R			bool	TRUE = ok	33022	0	(0x04)
776		extract air fan 3 to 16	bFanStateRepairSwitchETA4	repair switch of the extract air fan is active 4	R			bool	TRUE = ok	33022	1	(0x04)
777		extract air fan 3 to 16	bFanStateRepairSwitchETA5	repair switch of the extract air fan is active 5	R			bool	TRUE = ok	33022	2	(0x04)
778		extract air fan 3 to 16	bFanStateRepairSwitchETA6	repair switch of the extract air fan is active 6	R			bool	TRUE = ok	33022	3	(0x04)
779		extract air fan 3 to 16	bFanStateRepairSwitchETA7	repair switch of the extract air fan is active 7	R			bool	TRUE = ok	33022	4	(0x04)
780		extract air fan 3 to 16	bFanStateRepairSwitchETA8	repair switch of the extract air fan is active 8	R			bool	TRUE = ok	33022	5	(0x04)
781		extract air fan 3 to 16	bFanStateRepairSwitchETA9	repair switch of the extract air fan is active 9	R			bool	TRUE = ok	33022	6	(0x04)
782		extract air fan 3 to 16	bFanStateRepairSwitchETA10	repair switch of the extract air fan is active 10	R			bool	TRUE = ok	33022	7	(0x04)
783		extract air fan 3 to 16	bFanStateRepairSwitchETA11	repair switch of the extract air fan is active 11	R			bool	TRUE = ok	33022	8	(0x04)
784		extract air fan 3 to 16	bFanStateRepairSwitchETA12	repair switch of the extract air fan is active 12	R			bool	TRUE = ok	33022	9	(0x04)
785		extract air fan 3 to 16	bFanStateRepairSwitchETA13	repair switch of the extract air fan is active 13	R			bool	TRUE = ok	33022	10	(0x04)
786		extract air fan 3 to 16	bFanStateRepairSwitchETA14	repair switch of the extract air fan is active 14	R			bool	TRUE = ok	33022	11	(0x04)
787		extract air fan 3 to 16	bFanStateRepairSwitchETA15	repair switch of the extract air fan is active 15	R			bool	TRUE = ok	33022	12	(0x04)
788		extract air fan 3 to 16	bFanStateRepairSwitchETA16	repair switch of the extract air fan is active 16	R			bool	TRUE = ok	33022	13	(0x04)
789		electric preheater	bPreEHeatStateFlowDetector	electric preheater flow detector	R			bool	TRUE = ok	33024	0	(0x04)
790		electric preheater	bPreEHeatStateErrTempLimiter	electric preheater temperature limiter	R			bool	TRUE = ok	33024	1	(0x04)
791		electric preheater	bPreEHeatStateErrTempWarning	electric preheater temperature monitor	R			bool	TRUE = ok	33024	2	(0x04)
792	S	electric preheater	bPreEHeatCtrlON	controlled value operation signal of the electric preheater	R			bool	TRUE = on	33024	3	(0x04)
793	S	electric preheater	fPreEHeatCtrlPower	controlled value of the electric preheater power [0..100%]	R	%		uint		33025		(0x04)
794		electric reheater	bReEHeatStateFlowDetector	electric reheater flow detector	R			bool	TRUE = ok	33028	0	(0x04)
795		electric reheater	bReEHeatStateErrTempLimiter	electric reheater temperature limiter	R			bool	TRUE = ok	33028	1	(0x04)
796		electric reheater	bReEHeatStateErrTempWarning	electric reheater temperature monitor	R			bool	TRUE = ok	33028	2	(0x04)
797	S	electric reheater	bReEHeatCtrlON	controlled value operation signal of the electric reheater	R			bool	TRUE = on	33028	3	(0x04)
798	S	electric reheater	fReEHeatCtrlPower	controlled value of the electric reheater power [0..100%]	R	%		uint		33029		(0x04)
799	S	external chiller	bExternalChillerError	ext. chiller error	R			bool	TRUE = ok	33032	0	(0x04)
800	S	external chiller	bExternalChillerStateOn	ext. chiller operating	R			bool	TRUE = on	33032	1	(0x04)
801	S	external chiller	bExternalChillerCtrlOn	controlled value operation signal of the ext. chiller	R			bool	TRUE = on	33032	2	(0x04)
802	S	external chiller	fExternalChillerCtrlPower	controlled value of the ext. chiller power [0..100%]	R	%		uint		33033		(0x04)
803		humidifier	bHumidifierStateActive	humidifier active	R			bool	TRUE = active	33037	0	(0x04)
804	S	humidifier	bHumidifierStateError	humidifier error	R			bool	TRUE = ok	33037	1	(0x04)
805	S	humidifier	bHumidifierStateOn	humidifier operating	R			bool	TRUE = on	33037	2	(0x04)
806		humidifier	bHumidifierStateHygrostat	humidifier hygrostat	R			bool	TRUE = ok	33037	3	(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	datatype	values	register	bit	function code
807		humidifier	bHumidifierStateService	humidifier service	R			bool	TRUE = on	33037	4	(0x04)
808		humidifier	bHumidifierCtrlClean	controlled value to clean humidifier	R			bool	TRUE = on	33037	5	(0x04)
809	S	humidifier	bHumidifierCtrlOn	controlled value operation signal of the humidifier	R			bool	TRUE = on	33037	6	(0x04)
810	S	humidifier	fHumidifierCtrlPower	controlled value of the humidifier power [0..100%]	R	%		uint		33038		(0x04)
811	S	heat pump 1	bHeatPumpStateError1	heatpump 1 error	R			bool	TRUE = ok	33042	0	(0x04)
812	S	heat pump 1	bHeatPumpStateDeicing1	heatpump 1 deicing	R			bool	TRUE = active	33042	1	(0x04)
813	S	heat pump 1	bHeatPumpStateHeating1	heatpump 1 heating	R			bool	TRUE = active	33042	2	(0x04)
814	S	heat pump 1	bHeatPumpStateOperation1	heatpump 1 operating	R			bool	TRUE = active	33042	3	(0x04)
815	S	heat pump 1	bHeatPumpCtrlCooling1	controlled value cooling signal of the heatpump 1	R			bool	TRUE = on	33042	4	(0x04)
816	S	heat pump 1	bHeatPumpCtrlHeating1	controlled value heating signal of the heatpump 1	R			bool	TRUE = on	33042	5	(0x04)
817	S	heat pump 1	bHeatPumpCtrlRelease1	controlled value operation signal of the heatpump 1	R			bool	TRUE = on	33042	6	(0x04)
818	S	heat pump 1	fHeatPumpCtrlPower1	controlled value of the heatpump 1 power [0..100%]	R	%		uint		33043		(0x04)
819	S	heat pump 2	bHeatPumpStateError2	heatpump 2 error	R			bool	TRUE = ok	33047	0	(0x04)
820	S	heat pump 2	bHeatPumpStateDeicing2	heatpump 2 deicing	R			bool	TRUE = active	33047	1	(0x04)
821	S	heat pump 2	bHeatPumpStateHeating2	heatpump 2 heating	R			bool	TRUE = active	33047	2	(0x04)
822	S	heat pump 2	bHeatPumpStateOperation2	heatpump 2 operating	R			bool	TRUE = active	33047	3	(0x04)
823	S	heat pump 2	bHeatPumpCtrlCooling2	controlled value cooling signal of the heatpump 2	R			bool	TRUE = on	33047	4	(0x04)
824	S	heat pump 2	bHeatPumpCtrlHeating2	controlled value heating signal of the heatpump 2	R			bool	TRUE = on	33047	5	(0x04)
825	S	heat pump 2	bHeatPumpCtrlRelease2	controlled value operation signal of the heatpump 2	R			bool	TRUE = on	33047	6	(0x04)
826	S	heat pump 2	fHeatPumpCtrlPower2	controlled value of the heatpump 2 power [0..200%]	R	%		uint		33048		(0x04)
827		heat pump 3	bHeatPumpStateError3	heatpump 3 error	R			bool	TRUE = ok	33052	0	(0x04)
828		heat pump 3	bHeatPumpStateDeicing3	heatpump 3 deicing	R			bool	TRUE = active	33052	1	(0x04)
829		heat pump 3	bHeatPumpStateHeating3	heatpump 3 heating	R			bool	TRUE = active	33052	2	(0x04)
830		heat pump 3	bHeatPumpStateOperation3	heatpump 3 operating	R			bool	TRUE = active	33052	3	(0x04)
831		heat pump 3	bHeatPumpCtrlCooling3	controlled value cooling signal of the heatpump 3	R			bool	TRUE = on	33052	4	(0x04)
832		heat pump 3	bHeatPumpCtrlHeating3	controlled value heating signal of the heatpump 3	R			bool	TRUE = on	33052	5	(0x04)
833		heat pump 3	bHeatPumpCtrlRelease3	controlled value operation signal of the heatpump 3	R			bool	TRUE = on	33052	6	(0x04)
834		heat pump 3	fHeatPumpCtrlPower3	controlled value of the heatpump 3 power [0..300%]	R	%		uint		33053		(0x04)
835		heat pump 4	bHeatPumpStateError4	heatpump 4 error	R			bool	TRUE = ok	33057	0	(0x04)
836		heat pump 4	bHeatPumpStateDeicing4	heatpump 4 deicing	R			bool	TRUE = active	33057	1	(0x04)
837		heat pump 4	bHeatPumpStateHeating4	heatpump 4 heating	R			bool	TRUE = active	33057	2	(0x04)
838		heat pump 4	bHeatPumpStateOperation4	heatpump 4 operating	R			bool	TRUE = active	33057	3	(0x04)
839		heat pump 4	bHeatPumpCtrlCooling4	controlled value cooling signal of the heatpump 4	R			bool	TRUE = on	33057	4	(0x04)
840		heat pump 4	bHeatPumpCtrlHeating4	controlled value heating signal of the heatpump 4	R			bool	TRUE = on	33057	5	(0x04)
841		heat pump 4	bHeatPumpCtrlRelease4	controlled value operation signal of the heatpump 4	R			bool	TRUE = on	33057	6	(0x04)
842		heat pump 4	fHeatPumpCtrlPower4	controlled value of the heatpump 4 power [0..400%]	R	%		uint		33058		(0x04)
843		ext. run around coil system	bRacExtStateMotorProtection	error motor protection ext. rac pump	R			bool	TRUE = ok	33062	0	(0x04)
844		ext. run around coil system	bRacExtStateErrModbusValve	modbus comm. error with the ext. rac valve	R			bool	TRUE = ok	33062	1	(0x04)
845		ext. run around coil system	bRacExtCtrlPump	controlled value to switch on/off the ext. rac pump	R			bool	TRUE = on	33062	2	(0x04)
846		ext. run around coil system	fRacExtStateValve	current position of the ext. rac valve	R	%		uint		33063		(0x04)
847		ext. run around coil system	fRacExtMeaWaterTemp	present value of the ext. rac inlet temperature	R	°C	0.1	int		33064		(0x04)
848		ext. run around coil system	fRacExtCtrlValve	controlled value of the ext. rac valve	R	%		uint		33065		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	data type	values	register	bit	function code
849		<i>loop controller fans</i>	<i>nFanControlStrategy</i>	<i>control strategy fans</i>	<i>R</i>			<i>uint</i>	<i>0 = no control; 1 = supply pressure; 2 = extract pressure; 3 = pressure difference; 4 = CO2; 5 = VOC; 6 = supply flow; 7 = extract flow; 8 = extract temperature; 9 = supply and extract pressure; 10 = supply and extract flow; 11 = room temperature; 12 = supply flow and extract pressure; 13 = fan optimizer via X-AIRCONTROL</i>	33071		(0x04)
850	<i>S</i>	<i>loop controller fans</i>	<i>fFanSupSetpointAirflow</i>	<i>setpoint supply air flow</i>	<i>R</i>	<i>m³/h</i>	<i>10</i>	<i>uint</i>		33072		(0x04)
851	<i>S</i>	<i>loop controller fans</i>	<i>fFanSupCurrentValueAirflow</i>	<i>present value supply air flow</i>	<i>R</i>	<i>m³/h</i>	<i>10</i>	<i>uint</i>		33073		(0x04)
852	<i>S</i>	<i>loop controller fans</i>	<i>fFanSupSetpointPressure</i>	<i>setpoint supply air duct pressure</i>	<i>R</i>	<i>Pa</i>		<i>uint</i>		33074		(0x04)
853	<i>S</i>	<i>loop controller fans</i>	<i>fFanSupCurrentValuePressure</i>	<i>present value supply air duct pressure</i>	<i>R</i>	<i>Pa</i>		<i>uint</i>		33075		(0x04)
854		<i>loop controller fans</i>	<i>fFanSupActuatingValue</i>	<i>controlled value of the supply air fan</i>	<i>R</i>	<i>%</i>		<i>uint</i>		33076		(0x04)
855	<i>S</i>	<i>loop controller fans</i>	<i>fFanEtaSetpointAirflow</i>	<i>setpoint extract air flow</i>	<i>R</i>	<i>m³/h</i>	<i>10</i>	<i>uint</i>		33082		(0x04)
856	<i>S</i>	<i>loop controller fans</i>	<i>fFanEtaCurrentValueAirflow</i>	<i>present value extract air flow</i>	<i>R</i>	<i>m³/h</i>	<i>10</i>	<i>uint</i>		33083		(0x04)
857	<i>S</i>	<i>loop controller fans</i>	<i>fFanEtaSetpointPressure</i>	<i>setpoint extract air duct pressure</i>	<i>R</i>	<i>Pa</i>		<i>uint</i>		33084		(0x04)
858	<i>S</i>	<i>loop controller fans</i>	<i>fFanEtaCurrentValuePressure</i>	<i>present value extract air duct pressure</i>	<i>R</i>	<i>Pa</i>		<i>uint</i>		33085		(0x04)
859		<i>loop controller fans</i>	<i>fFanEtaActuatingValue</i>	<i>controlled value of the extract air fan</i>	<i>R</i>	<i>%</i>		<i>uint</i>		33086		(0x04)
860		<i>loop controller temperature</i>	<i>nTemperatureControlStrategy</i>	<i>control strategy temperature</i>	<i>R</i>			<i>uint</i>	<i>0 = no control; 1 = supply; 2 = extract; 3 = supply-extract cascade; 4 = room; 5 = supply-room cascade; 6 = supply via X-AIRCONTROL</i>	33092		(0x04)
861		<i>loop controller temperature</i>	<i>fSupTempSetpointLowLimit</i>	<i>min. supply air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33093		(0x04)
862		<i>loop controller temperature</i>	<i>fSupTempSetpointHighLimit</i>	<i>max. supply air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33094		(0x04)
863	<i>S</i>	<i>loop controller temperature</i>	<i>fSupTempSetpointCurrent</i>	<i>current supply air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33095		(0x04)
864	<i>S</i>	<i>loop controller temperature</i>	<i>fSupTempCurrentValue</i>	<i>present value supply air temperature</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33096		(0x04)
865		<i>loop controller temperature</i>	<i>fEtaTempSetpointLowLimit</i>	<i>min. extract air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33097		(0x04)
866		<i>loop controller temperature</i>	<i>fEtaTempSetpointHighLimit</i>	<i>max. extract air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33098		(0x04)
867	<i>S</i>	<i>loop controller temperature</i>	<i>fEtaTempSetpointCurrent</i>	<i>current extract air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33099		(0x04)
868	<i>S</i>	<i>loop controller temperature</i>	<i>fEtaTempCurrentValue</i>	<i>present value extract air temperature</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33100		(0x04)
869		<i>loop controller temperature</i>	<i>fRoomTempSetpointLowLimit</i>	<i>min. room air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33101		(0x04)
870		<i>loop controller temperature</i>	<i>fRoomTempSetpointHighLimit</i>	<i>max. room air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33102		(0x04)
871	<i>S</i>	<i>loop controller temperature</i>	<i>fRoomTempSetpointCurrent</i>	<i>current room air temperature setpoint</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33103		(0x04)
872	<i>S</i>	<i>loop controller temperature</i>	<i>fRoomTempCurrentValue</i>	<i>present value room air temperature</i>	<i>R</i>	<i>°C</i>	<i>0.1</i>	<i>uint</i>		33104		(0x04)
873		<i>loop controller temperature</i>	<i>fTempMeanActuatingvalue</i>	<i>mean value of actuating values temperature control</i>	<i>R</i>	<i>%</i>		<i>uint</i>		33105		(0x04)

Data point list Modbus/TCP X-CUBE Control

D: important data points

S: system specific data points

default IP address: 192.168.0.180 OR 192.168.0.200

Modbus/TCP port: 502

no.	D/S	group	datapoint	description	R/W	unit	scale	data type	values	register	bit	function code
874		<i>loop controller humidity</i>	<i>nHumidityControlStrategy</i>	<i>control strategy humidity</i>	<i>R</i>			<i>uint</i>	<i>0 = no control; 1 = supply; 2 = extract; 3 = supply-extract cascade; 4 = room; 5 = supply-room cascade;</i>	33111		(0x04)
875		<i>loop controller humidity</i>	<i>fSupHumSetpointLowLimit</i>	<i>min. supply air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33112		(0x04)
876		<i>loop controller humidity</i>	<i>fSupHumSetpointHighLimit</i>	<i>max. supply air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33113		(0x04)
877	S	<i>loop controller humidity</i>	<i>fSupHumSetpointCurrent</i>	<i>current supply air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33114		(0x04)
878	S	<i>loop controller humidity</i>	<i>fSupHumCurrentValue</i>	<i>present value supply air humidity</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33115		(0x04)
879		<i>loop controller humidity</i>	<i>fEtaHumSetpointLowLimit</i>	<i>min. extract air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33116		(0x04)
880		<i>loop controller humidity</i>	<i>fEtaHumSetpointHighLimit</i>	<i>max. extract air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33117		(0x04)
881	S	<i>loop controller humidity</i>	<i>fEtaHumSetpointCurrent</i>	<i>current extract air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33118		(0x04)
882	S	<i>loop controller humidity</i>	<i>fEtaHumCurrentValue</i>	<i>present value extract air humidity</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33119		(0x04)
883		<i>loop controller humidity</i>	<i>fRoomHumSetpointLowLimit</i>	<i>min. room air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33120		(0x04)
884		<i>loop controller humidity</i>	<i>fRoomHumSetpointHighLimit</i>	<i>max. room air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33121		(0x04)
885	S	<i>loop controller humidity</i>	<i>fRoomHumSetpointCurrent</i>	<i>current room air humidity setpoint</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33122		(0x04)
886	S	<i>loop controller humidity</i>	<i>fRoomHumCurrentValue</i>	<i>present value room air humidity</i>	<i>R</i>	<i>g/kg</i>	<i>0.01</i>	<i>uint</i>		33123		(0x04)
887		<i>loop controller humidity</i>	<i>fHumMeanActuatingvalue</i>	<i>mean value of actuating values humidity control</i>	<i>R</i>	<i>%</i>		<i>uint</i>		33124		(0x04)
888	S	<i>loop controller air quality</i>	<i>fAirQualitySetpoint</i>	<i>setpoint air quality</i>	<i>R</i>	<i>ppm</i>		<i>uint</i>		33130		(0x04)
889	S	<i>loop controller air quality</i>	<i>fAirQualityCurrentValue</i>	<i>present value air quality</i>	<i>R</i>	<i>ppm</i>		<i>uint</i>		33131		(0x04)
890		<i>loop controller air quality</i>	<i>fAirQualityActuatingValueRCA</i>	<i>Actuating value recirculation air damper</i>	<i>R</i>	<i>%</i>		<i>uint</i>		33132		(0x04)
891		<i>loop controller air quality</i>	<i>fAirQualityActuatingValueSupFan</i>	<i>Actuating value supply air fan</i>	<i>R</i>	<i>m³/h</i>	<i>10</i>	<i>uint</i>		33133		(0x04)
892		<i>loop controller air quality</i>	<i>fAirQualityActuatingValueEtaFan</i>	<i>Actuating value extract air fan</i>	<i>R</i>	<i>m³/h</i>	<i>10</i>	<i>uint</i>		33134		(0x04)